



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 7, 2008

RE: PIOUS SOCIETY OF ST. PAUL
9531 WEST AKRON-CANFIELD ROAD
NPDES PERMITNO. 3PR00224

NOTICE OF VIOLATION

Br. Aloysius Milella
Pious Society of St. Paul
P.O. Box 595
Canfield, OH 44406

Dear Br. Milella:

A review of monitoring data shows that over the period covering June through October 2007, the Pious Society of St. Paul is listed as being in Significant Noncompliance with the NPDES Permit limits for chlorine. All of the permit violations identified during the review period are as follows.

Station	Parameter	Limit Type	Limit	Reported Value	Units	Violation Date
001	Fecal Coliform	30D Conc	1000	2800.	#/100 ml	6/1/2007
						6/15/200
001	Fecal Coliform	7D Conc	2000	2800.	#/100 ml	7
	Chlorine, Total					6/18/200
001	Residual Chlorine, Total	1D Conc	0.019	.57	mg/l	7
001	Residual Chlorine, Total	1D Conc	0.019	.38	mg/l	8/7/2007

The Pious Society of St. Paul must provide a written response to this office indicating actions that have or will be taken to bring the treatment system into compliance with the NPDES Permit. The response should be provided no later than January 25, 2008.

The Pious Society of St. Paul must install a de-chlorination system. This requirement for de-chlorination was addressed in the compliance schedule included in Part I.C of the current NPDES Permit.


The response to this Notice of Violation must include a schedule for installing a new de-chlorination system capable of compliance with the final NPDES Permit limit. The schedule must not extend more than 12 months from the date of this letter.

PIOUS SOCIETY OF ST. PAUL
JANUARY 7, 2008
PAGE 2 OF 2

Be advised that in accordance with Ohio Administrative Code 3745-42, a Permit-to-Install from the Director of Ohio EPA must be received prior to installation of the de-chlorination system. Continued violations of the NPDES Permit are subject to enforcement action per Ohio Revised Code 6111.

You may contact this writer at (330) 963-1251 to discuss any questions you may have.

Respectfully,

A handwritten signature in black ink, appearing to read "John Kwolek". The signature is written in a cursive style with a large, sweeping initial "J".

John Kwolek
District Engineer
Division of Surface Water

JK:bo

cc. Joe Mansky, Mahoning County Department of Health