



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 22, 2010

RE: PORTAGE COUNTY
EDINBURG TOWNSHIP
THE DIAMOND LODGE
3116 STATE ROUTE 14
NPDES #3PR00505

Mr. Mario Gallo
3116 State Route 14
Edinburg, OH 44272

Dear Mr. Gallo:

This office and the Portage County Health Department conducted an inspection at the above facility on March 19, 2010.

At the time of our inspection no one was at the facility. The package plant was running and the following operational issues were noted:

1. The skimmer in the settling tank was plugged and not working. By adjusting the air I was able to get it functioning again. It should be evaluated by your operator to determine if additional maintenance is necessary.
2. Sludge in the clarifier had bulked and was floating on the surface.

To date, we have not received any discharge monitoring reports from the facility. Monthly reports are required and sampling is to be conducted in accordance with the effective permit for the facility. Failure to submit reports and failure to monitor the discharge are violations of your effective permit.

The permit was effective on January 1, 2010. A compliance schedule in the permit requires submission of a conceptual design plan by May 1, 2010 and submission of detail plans and a permit to install application by November 1, 2010.

Should you have further questions please call me at (330) 963-1134.

Sincerely,

William J. Zawiski
Environmental Scientist
Division of Surface Water

WJZ/mt

cc: Rich Lashley, Portage County Health Department