



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

RE: Notice of Violation  
Van Wert County  
Van Wert WWTP;  
Ohio EPA Permit No. 2PD00006  
NPDES Permit No. OH0027910

January 4, 2010

Mr. Robert J. Hornic  
WWTP Superintendent  
City of Van Wert  
515 East Main Street  
Van Wert, OH 45891

Dear Mr. Hornic:

We are in receipt of your self-monitoring report covering the months of July through September 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet.


Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

Mr. Robert Hornic  
January 4, 2010  
Page Two

If there are any questions, please contact Mr. Justin Williams at (419) 373 – 3022.

Sincerely,



Elizabeth A. Wick, P.E.  
District Engineer/Unit Supervisor  
Division of Surface Water

JAW/lb

Enclosure

CPc w/Enclosure: NWDO – DSW File

Get New Data

Violations for Van Wert WWTTP - July-September 2009

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PD00006*RD	September 2009	001	00400	pH	1D Conc	6.5	4.6	9/11/2009
2PD00006*RD	September 2009	001	00400	pH	1D Conc	6.5	6.1	9/14/2009