



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Van Wert County
Willshire WWTP
Ohio EPA Permit No. 2PA00013
NPDES Permit No. OH0031003

November 14, 2008

Mr. David Carr
WWTP & WTP Superintendent
Village of Willshire
P. O. Box 110
Willshire, Ohio 45898

Dear Mr. Carr:

We are in receipt of your self-monitoring report covering the months of July 2008, through September 2008, for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance is attached on a separate sheet.


Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

Mr. David Carr
November 14, 2008
Page 2

If there are any questions, feel free to contact me at (419) 373- 3022.

Sincerely,



Justin A. Williams
Division of Surface Water

/lr

Enclosure

pc w/Enclosure: DSW-NWDO File

Get New Data

Willsboro WLP - July-September 2008 Violations

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PA00013*FD	August 2008	001	31616	Fecal Coliform	7D Conc	2000	20000.	8/1/2008