



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 27, 2007

**Re: Franklin County
Pickerington Ponds-Bowen
Transient Non-Community
PWS ID #2556312**

Franklin County Metro Parks
Pickerington Ponds-Bowen
1069 West Main Street
Westerville, OH 43081

Subject: Additional Total Coliform Samples Required

Ohio EPA has received the following total coliform sample result(s) from your public water system. The bacteriological analyses is as follows:

Sample Date	Sample Location	Total Coliform	E. Coli
September 18, 2007	Bowen Area	Positive	Negative

Please note: When a total coliform-positive sample (contains coliforms) is reported, Ohio Administrative Code 3745-81-21 requires additional sampling.

Actions required as a result of the above sample result:

1. Collect four repeat samples within 24 hours of being notified of the total coliform-positive sample (contains coliforms) result. See the attached fact sheet "What to Do after a Routine Total Coliform Positive Sample Result" for more detailed repeat sampling instructions.

Clearly mark "Repeat Sample" on each repeat sample slip. Write on the repeat sample slip the sample number that the lab assigned to the original total coliform-positive sample.

2. If any of the repeat samples are total coliform-positive (contains coliforms), contact me at the phone number below. Additional sets of four repeat samples are required until total coliforms are not detected in one complete set.
3. You must monitor with at least five (5) samples in the next month following the original total coliform-positive result.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Franklin County Metro Parks
Pickerington Ponds-Bowen
Page -2-

If you have any questions, please contact me at (614) 728-3874.

Sincerely,



Raymond Shesky
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures

c: Toni Buchanan, DDAGW, CO
Franklin County Health Department
CDO File

RS/nsm 2556312 pos. not.