



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Williams County
Lakeland Woods Subdivision
Recon

April 4, 2008

Mr. Dennis M. Bell, P.E., P.S., Williams County Engineer
Williams County Engineer's Department
12953 County Road G
Bryan, OH 43506

Dear Mr. Bell:

On March 18, 2008, an inspection was made of the wastewater treatment plant that serves the Lakeland Woods Subdivision.

At the time of inspection, the southeast and southwest sand beds were ponded due to recent wet weather. The cracks from which wastewater once leaked had been sealed. The contents of the ponded sand beds were being directed to the clean northwest sand bed. There were no signs of sludge on the bank of the ditch.

We appreciate your fast response to the issues at this plant. We look forward to the results of the inflow and infiltration study you are conducting. If you have any questions, please feel free to call Tanushree Courlas at 419-373-3053.

Yours truly,

Elizabeth Wick, P.E.
District Engineer, Unit Supervisor
Division of Surface Water

/csl

pc: Williams County Commissioners
DSW:NWDO:File