

Montpelier WWTP
Blue



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Williams County
Ohio EPA Permit No. 2PD00003
NPDES Permit No. OH0021831

April 18, 2008

Mayor & Council
Village of Montpelier
211 North Jonesville Street
P.O. Box 148
Montpelier, Ohio 43543

Dear Mayor and Council:

We are in receipt of your self monitoring reports covering the months of January to March 2008, for the referenced facility. Our review indicates violations of the conditions of your NPDES permit for Station 2PD00003001. The specific instances of noncompliance are as follows:

Reporting Period	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
January 2008	00530	Total Suspended Solids	7D Conc	45	50.6666	1/22/2008
January 2008	00530	Total Suspended Solids	7D Qty	171	213.463	1/22/2008
January 2008	80082	CBOD 5 day	7D Qty	151	178.636	1/22/2008
February 2008	00530	Total Suspended Solids	30D Conc	30	48.9166	2/1/2008
February 2008	00530	Total Suspended Solids	7D Conc	45	52.3333	2/1/2008
February 2008	00530	Total Suspended Solids	30D Qty	114	234.307	2/1/2008
February 2008	00530	Total Suspended Solids	7D Qty	171	271.756	2/1/2008
February 2008	80082	CBOD 5 day	30D Qty	95	113.983	2/1/2008
February 2008	80082	CBOD 5 day	7D Qty	151	151.321	2/1/2008
February 2008	00530	Total Suspended Solids	7D Conc	45	67.3333	2/8/2008
February 2008	00530	Total Suspended Solids	7D Qty	171	333.305	2/8/2008

Reporting Period	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2008	00530	Total Suspended Solids	7D Conc	45	53.6666	2/22/2008
February 2008	00530	Total Suspended Solids	7D Qty	171	212.184	2/22/2008
March 2008	00530	Total Suspended Solids	30D Conc	30	53.5	3/1/2008
March 2008	00530	Total Suspended Solids	7D Conc	45	54.6666	3/1/2008
March 2008	00530	Total Suspended Solids	30D Qty	114	286.728	3/1/2008
March 2008	00530	Total Suspended Solids	7D Qty	171	229.259	3/1/2008
March 2008	80082	CBOD 5 day	30D Conc	25	31.3333	3/1/2008
March 2008	80082	CBOD 5 day	30D Qty	95	160.254	3/1/2008
March 2008	80082	CBOD 5 day	7D Qty	151	163.077	3/1/2008
March 2008	00530	Total Suspended Solids	7D Conc	45	116.	3/8/2008
March 2008	00530	Total Suspended Solids	7D Qty	171	654.459	3/8/2008
March 2008	80082	CBOD 5 day	7D Conc	40	66.	3/8/2008
March 2008	80082	CBOD 5 day	7D Qty	151	348.463	3/8/2008
March 2008	00530	Total Suspended Solids	7D Qty	171	200.915	3/15/2008

Please inform this office in writing within 10 days of receipt of this letter as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs.

Mayor and Council
April 18, 2008
Page 3

For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact this office.

Yours truly,



Tanushree Courlas
Environmental Specialist II
Division of Surface Water

/llr

pc: ~~DSW-NWDO.File~~