



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Wood County
Eastwood School WWTP
Ohio EPA Permit No. 2PT00026*AD
NPDES Permit No. OH0126551

December 31, 2008

Mr. William McFarland, Superintendent
Eastwood Local Board of Education
4800 Sugar Ridge Road
Pemberville, OH 43450

Dear Mr. McFarland:

A review of your discharge monitoring reports for the referenced facility covering the months of March, 2005 through November, 2008 indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are enclosed on a separate sheet.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in Part III - General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://www.epa.state.oh.us/ocapp/ocapp.html> or by calling (614) 644-3469.

If you have any questions, please feel free to contact this office.

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/lb

enclosure

pc: ~~DSW-NWDO file~~

Eastwood Schools
Violations for the Period of 03/1/05 through 11/30/08

date	station	rptcode	parameter	lmttype	limit	rptvalue
07/13/06	001	31616	Fecal Coliform	week	2000	AK
02/01/07	001	00010	Water Temperature	frequency	1/Week	none
02/01/07	001	00300	Dissolved Oxygen	frequency	1/Week	none
02/15/07	001	00300	Dissolved Oxygen	frequency	1/Week	none
02/15/07	001	00010	Water Temperature	frequency	1/Week	none
02/22/07	001	00300	Dissolved Oxygen	frequency	1/Week	none
02/22/07	001	00010	Water Temperature	frequency	1/Week	none
05/01/07	001	31616	Fecal Coliform	frequency	1/Month	none
05/08/07	001	50060	Chlorine,	frequency	1/Week	none
05/22/07	001	50060	Chlorine	frequency	1/Week	none
06/01/07	001	50060	Chlorine	frequency	1/Week	none
06/15/07	001	50060	Chlorine	frequency	1/Week	none
04/01/08	001	80082	CBOD 5 day	30D Conc	10	23
04/01/08	001	80082	CBOD 5 day	30D Qty	0.76	1.57
04/10/08	001	80082	CBOD 5 day	1D Qty	1.14	3.13
04/10/08	001	80082	CBOD 5 day	1D Conc	15	46