



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

August 23, 2010

Wood County  
2PA00080\*HD

Mayor and Council  
Village of Luckey  
226 Main Street, P.O. Box 384  
Luckey, OH 43443

Re: Notice of Violation: Village of Luckey Collection System/Combined Sewer  
Overflow Inspection

Dear Mayor and Council:

On August 2, 2010, Ohio EPA staff members Pat Tebbe and I met with Village Administrator George Jensen to conduct a Collection System Inspection for the Village of Luckey. The following are comments from the inspection:

- The Village is in violation of National Pollutant Discharge Elimination System (NPDES) permit requirements regarding Combined Sewer Overflow elimination.
- The Village should develop a routine Operation & Maintenance program for its sanitary sewer system.

Luckey's NPDES permit requires elimination of all CSOs by December 31, 2008. It was reported during this inspection that three of the four overflows listed in the NPDES permit still remain open. It was also stated that the bid for the final construction project to remove all remaining storm connections from the three pump stations associated with these remaining overflows has been awarded. Following completion of this project it is expected that all CSOs will be eliminated. The exact schedule for this project was not known at the time of this inspection, but it was conveyed that it would be complete by no later than the end of 2010. The Village of Luckey should send notification to Ohio EPA's Northwest district office within fourteen (14) days of completing this project and eliminating all CSOs. Please send an additional copy of that letter to this office.

It was also stated during the inspection that all combined sewers have been separated by means of installing new sanitary sewers throughout the Village. This work was completed during December of 2007. Connection of all private users to the collection

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



August 23, 2010

Page Two

system was completed during the fall of 2009 with all existing septic tanks being crushed and abandoned. It is understood by this office that operation and maintenance of the wastewater treatment lagoon and pump stations is the responsibility of the Northwestern Sewer and Water District. At the same time, Luckey is advised that operation and maintenance of the sanitary collection sewers is the responsibility of the Village. Performing routine inspections, cleaning activities, and implementing any necessary repair work or other maintenance measures for the collection lines and manholes are critical to protect the Village's significant investment and to maintain a properly functioning system.

If you have questions/concerns regarding this letter, I can be reached by telephone at (614) 644-2118 or email at [dan.gill@epa.state.oh.us](mailto:dan.gill@epa.state.oh.us).

Sincerely,



Daniel P. Gill  
Environmental Specialist  
Division of Surface Water, Ohio EPA, Central Office

cc: George Jensen, Luckey  
DSW-CO File

ec: Pat Tebbe, DSW, NWDO