



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Wood County
Maurer Mobile Home Park
Ohio EPA Permit No. 2PY00005
NPDES Permit No. OH00278450

January 8, 2009

Mr. Allen Steinke, President
Maurer Mobile Home Court, Inc.
17910 N. Dixie Hwy.
Bowling Green, OH 43402

Dear Mr. Steinke:

A review of the discharge monitoring reports covering the months of April, 2007 through November, 2008 indicates violations of the conditions of the NPDES permit for the Maurer MHP WWTP. The specific instances of noncompliance are enclosed on a separate table.

In addition to the list of attached violations, we do not have record for the receipt of the March, July, and November, 2008 reports.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in Part III - General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://www.epa.state.oh.us/ocapp/ocapp.html> or by calling (614) 644-3469.

Please inform this office in writing, within 10 days of receipt of this letter, as to the description of the actions taken or proposed to prevent further violations of this nature. Your response should include the dates, either actual or proposed, for completion of the actions.

Mr. Allen Steinke
January 8, 2009
Page 2

If you have any questions, please feel free to contact this office.

Sincerely,

A handwritten signature in cursive script that reads "Patricia A. Tebbe". The signature is written in black ink and is positioned above the typed name.

Patricia A. Tebbe, P.E.
Division of Surface Water

/csl

Enclosure

pc: Tom Behlen, EES/AGO
Chad Johnson, Bowling Green WTP
DSW-NWDO file

Maurer MHP WWTP
Violation Summary
April 1, 2007 though November 30, 2008

Date	Station	viotype	rptcode	parameter	lmtype	limit	rptvalue
April-07							
04/01/07	001	Freq	00300	Dissolved Oxygen	4/month	4	0
04/15/07	001	Limit	00530	Suspended Solids	7D Qty	2	2.05904
May-07							
05/01/07	001	Freq	00300	Dissolved Oxygen	4/month	4	0
06/01/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
June-07							
06/08/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
06/15/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
06/22/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
July-07							
07/01/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
07/08/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
07/15/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
07/22/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
August-07							
08/01/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
08/01/07	001	Limit	31616	Fecal Coliform	30D Conc	1000	7200.
08/08/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
08/15/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
08/22/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
08/23/07	001	Limit	31616	Fecal Coliform	1D Conc	2000	7200.
September-07							
09/01/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
09/08/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
09/15/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
09/22/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
October-07							
10/01/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
10/08/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
10/15/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
10/22/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
November-07							
11/01/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
11/08/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
11/15/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
11/22/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0

Maurer MHP WWTP
Violation Summary
April 1, 2007 though November 30, 2008

Date	Station	viotype	rptcode	parameter	lmttype	limit	rptvalue
December-07							
12/01/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
12/08/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
12/15/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
12/22/07	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
January-08							
01/01/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
01/08/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
01/15/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
01/22/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
April-08							
04/01/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
04/08/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
04/15/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
04/22/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
May-08							
05/01/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
05/08/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
05/15/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
05/22/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
June-08							
06/01/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
06/08/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
06/15/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
06/22/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
06/30/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
06/30/08	001	Freq	50050	Flow Rate	1/Day	1	0
06/30/08	001	Freq	00010	Water Temperature	1/Day	1	0
August-08							
08/01/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
08/08/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
08/15/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
08/22/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
September-08							
09/01/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
09/02/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/03/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/04/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/05/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/08/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
09/08/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0

Maurer MHP WWTP
 Violation Summary
 April 1, 2007 though November 30, 2008

Date	Station	viotype	rptcode	parameter	lmttype	limit	rptvalue
September-08							
09/09/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/10/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/11/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/12/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/15/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/15/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
09/16/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/17/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/18/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/19/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/22/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/22/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0
09/23/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/24/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/25/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/26/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/29/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
09/30/08	001	Freq	50060	Chlorine, Total Residu	1/Day	1	0
October-08							
10/14/08	001	Limit	50060	Chlorine, Total Residu	1D Conc	0.038	.14
10/20/08	001	Limit	50060	Chlorine, Total Residu	1D Conc	0.038	.27
10/22/08	001	Freq	00400	pH	1/Week	1	0
10/22/08	001	Freq	00300	Dissolved Oxygen	1/Week	1	0