



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Wood County
Williamsburg on the River WWTP
Ohio EPA Permit No. 2PG00097
NPDES Permit No. OH0029491

January 16, 2009

Mr. Jerry Greiner, Executive Director
Northwestern Water and Sewer District
PO Box 348
Bowling Green, OH 43402

Dear Mr. Greiner:

A review of the self-monitoring reports for the Williamsburg on the River wastewater treatment plant (WWTP) covering the months of October 2006 through December 2008 indicates violations of the conditions of your National Pollutant Discharge Elimination System (NPDES) permit. The specific instances of noncompliance are enclosed.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in Part III - General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://www.epa.state.oh.us/ocapp/ocapp.html> or by calling (614) 644-3469.

If you have any questions, please feel free to contact this office.

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/lb

pc: Dan Wickard, NWWSD

~~DSW/NWDO-tte~~



Williamsburg on the River WWTP
 Violation Summary
 October 1, 2006 though November 30, 2008

date	station	viotype	rptcode	parameter	lmttype	limit	rptvalue
May, 2007							
05/01/07	001	Limit	00530	Suspended Solids	30D Qty	5.7	14.7
05/01/07	001	Limit	00530	Suspended Solids	7D Qty	8.6	15.8
05/01/07	001	Limit	80082	CBOD 5 day	30D Qty	4.7	7.2
05/08/07	001	Limit	00530	Suspended Solids	7D Qty	8.6	18.7
05/08/07	001	Limit	80082	CBOD 5 day	7D Qty	7.6	8.6
05/15/07	001	Limit	00530	Suspended Solids	7D Qty	8.6	11.5
05/22/07	001	Limit	00530	Suspended Solids	7D Qty	8.6	12.9
June, 2007							
06/26/07	001	Limit	00400	pH	1D Conc	6.5	6.4
July, 2007							
07/01/07	001	Limit	00530	Suspended Solids	30D Qty	5.7	16.2
07/01/07	001	Limit	80082	CBOD 5 day	30D Qty	4.7	5
07/01/07	001	Limit	00530	Suspended Solids	7D Qty	8.6	31.6
07/03/07	001	Limit	00400	pH	1D Conc	6.5	5.6
07/08/07	001	Limit	00530	Suspended Solids	7D Qty	8.6	10.1
07/15/07	001	Limit	00530	Suspended Solids	7D Qty	8.6	10.1
07/24/07	001	Limit	00400	pH	1D Conc	6.5	6.1
October, 2007							
10/09/07	001	Limit	00400	pH	1D Conc	6.5	6.2
February, 2008							
02/01/08	001	Limit	00530	Suspended Solids	7D Conc	45	62
02/01/08	001	Limit	00530	Suspended Solids	7D Qty	8.6	8.9
November, 2008							
11/12/08	001	Limit	00400	pH	1D Conc	6.5	6.2