



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

December 14, 2009

Rick Cashman
National Fruit & Vegetable Technology
210 Water Street
Baltimore, OH 43105

Re: Facility Pretreatment Reconnaissance Inspection (4DP00010)

Dear Mr. Cashman:

I conducted reconnaissance inspections on December 3, 2009. The purpose of the site visits were to evaluate the discharges to the east and west storm water outfalls. The following were noted during the inspections:

1. The west storm water outfall had water standing in the ditch and it appeared gray in color. The gray color usually represents sewage in the discharge.
2. The east storm water outfall had a little flow and there was no rain the previous two days prior to the December 3, 2009, inspection. It appears the flow in the east storm water outfall is from non-contact cooling water. Please submit an application for the discharge of non-contact cooling water. You may obtain the application from the following weblink: http://epa.ohio.gov/dsw/permits/GP_NonContactCoolingWater.aspx
3. I am currently reviewing your submittal dated October 15, 2009. I will address this review under separate cover letter.
4. I have noted that you have submitted a request to land apply potato peels to Phil Farnlarcher in the Division of Solid and Infectious Waste Management in Central District Office at the Ohio Environmental Protection Agency.

Ohio EPA looks forward to working with National Fruit & Vegetable Technology to ensure continuing compliance with pretreatment requirements and the indirect discharge permit. Please submit the above action items within 14 days from the date of this letter.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Rick Cashman
National Fruit & Vegetable Technology
Page -2-

If you need additional information or assistance, please feel free to contact me by e-mail at:
greg.sanders@epa.state.oh.us or phone at (614) 728-3851.

Sincerely,



Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

Enclosure

c: Dennis Rose, Utilities Director, Village of Baltimore
Ryan Laake, Ohio EPA/DSW/CO

GLS/nsm 3December2009Cov. Ltr. National Fruit & Vegetable.wpd

State of Ohio Environmental Protection Agency

NPDES PERMIT NUMBER OHP000110	FACILITY PERMIT NUMBER 4DP00010*CP	DATE CONDUCTED December 3, 2009
INSPECTION TYPE R	INSPECTOR S	FACILITY TYPE 2
		TIME IN TIME OUT 3:40 pm 4:00 pm

GENERAL INFORMATION	
Name and Location of Facility National Fruit & Vegetable Technology Corporation 210 Water Street Baltimore, OH 43105	POTW Receiving Discharge Village of Baltimore
Mailing Address of Facility same	Categorical Standard(s) or other Classification Non-Categorical Significant User
Contact (Name/Title/Phone) Rick Cashman, CEO 740.862.6300	Other Notes: Recon inspection to check water quality in east & west storm water outfalls.

FACILITY EVALUATION (S - Satisfactory, M - Marginal, U - Unsatisfactory, NE - Not Evaluated, O - Other)			
NE	General Facility Operation	U	Pretreatment System - inspected east & west storm water outfalls. No permit for non-contact cooling water discharge. West outfall flowing full and grayish in color.
NE	Permit Compliance (Effluent Limitations)	NE	Self-Monitoring and Reporting

Name and Signature of Inspector	Agency / Office / Telephone	Date
Gregory L. Sanders 	OEPA/DSW/CDO/(614)728-3851	December 9, 2009
Signature of Reviewer	Agency / Office	Date
Jeff Bohne, Supervisor; Water Quality 	OEPA/DSW/CDO/(614)728-3841	12-18-09