



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Wood County
Pemberville WWTP
Ohio EPA Permit No. 2PB00012
NPDES Permit No. OH0026972

October 22, 2008

Village of Pemberville
Board of Public Affairs
115 Main Street
PO Box 109
Pemberville, OH 43450

Dear Board Members:

A review of the self-monitoring reports for the referenced facility covering the months of August, 2006 through August, 2008 indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are enclosed on a separate table.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in Part III - General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://www.epa.state.oh.us/ocapp/ocapp.html> or by calling (614) 644-3469.

Village of Pemberville
October 22, 2008
Page Two

Please inform this office in writing, within 10 days of receipt of this letter, as to the description of the actions taken or proposed to prevent further violations of this nature. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions, please feel free to contact this office.

Sincerely,



Patricia A. Tebbe, P.E.
Division of Surface Water

/lb

Enclosure

pc: Brian Heestand, Sewer Superintendent w/encl

~~DSW-NWDO file~~

Village of Pemberville
 NPDES Permit Limit Violations August, 2006 through August 2008

date	viotype	rptcode	parameter	lmttype	limit	rptvalue
08/15/06	Limit	00610	Ammonia	7D Conc	3	3.30
10/01/06	Limit	00610	Ammonia	30D loading	1.5	2.17
10/15/06	Limit	00530	Suspended Solids	7D loading	14	22.55
10/15/06	Limit	00610	Ammonia	7D Conc	3	5.21
10/15/06	Limit	00610	Ammonia	7D loading	2.3	6.21
10/15/06	Limit	80082	CBOD 5 day	7D loading	11	13.72
11/01/06	Limit	00530	Suspended Solids	30D loading	9.1	10.02
11/15/06	Limit	00530	Suspended Solids	7D loading	14	25.47
03/01/07	Limit	00530	Suspended Solids	30D Conc	12	14.75
03/01/07	Limit	00530	Suspended Solids	30D loading	9.1	19.12
03/01/07	Limit	80082	CBOD 5 day	7D loading	11	15.54
03/01/07	Limit	80082	CBOD 5 day	30D loading	7.6	13.06
03/01/07	Limit	00530	Suspended Solids	7D loading	14	14.05
03/15/07	Limit	80082	CBOD 5 day	7D loading	11	16.25
03/15/07	Limit	00530	Suspended Solids	7D loading	14	29.05
03/15/07	Limit	00530	Suspended Solids	7D Conc	18	19.00
03/22/07	Limit	00530	Suspended Solids	7D loading	14	20.40
03/22/07	Limit	80082	CBOD 5 day	7D loading	11	11.86
04/01/07	Limit	00530	Suspended Solids	30D loading	9.1	13.77
04/01/07	Limit	00530	Suspended Solids	30D Conc	12	12.50
04/01/07	Limit	80082	CBOD 5 day	30D loading	7.6	15.25
04/08/07	Limit	00530	Suspended Solids	7D loading	14	18.20
04/22/07	Limit	80082	CBOD 5 day	7D Conc	15	28.50
04/22/07	Limit	00530	Suspended Solids	7D loading	14	23.96
04/22/07	Limit	80082	CBOD 5 day	7D loading	11	52.18
05/01/07	Limit	00530	Suspended Solids	7D loading	14	18.27
06/08/07	Limit	00530	Suspended Solids	7D Conc	18	20.00
06/15/07	Limit	80082	CBOD 5 day	7D Conc	15	18.50
06/22/07	Limit	31616	Fecal Coliform	7D Conc	2000	2200
07/01/07	Limit	00530	Suspended Solids	30D Conc	12	17.75
07/15/07	Limit	80082	CBOD 5 day	7D Conc	15	29.00
07/15/07	Limit	00530	Suspended Solids	7D loading	14	20.42
07/15/07	Limit	00530	Suspended Solids	7D Conc	18	41.50
07/15/07	Limit	80082	CBOD 5 day	7D loading	11	14.29
08/01/07	Limit	00530	Suspended Solids	30D loading	9.1	10.09
08/22/07	Limit	00530	Suspended Solids	7D loading	14	29.26
12/01/07	Limit	00530	Suspended Solids	30D loading	9.1	13.10
12/08/07	Limit	00530	Suspended Solids	7D Conc	18	19.00
12/08/07	Limit	00530	Suspended Solids	7D loading	14	36.43

Village of Pemberville
NPDES Permit Limit Violations August, 2006 through August 2008

02/01/08	Limit	00530	Suspended Solids	30D loading	9.1	9.81
02/01/08	Limit	00530	Suspended Solids	7D loading	14	21.55
07/15/08	Limit	00530	Suspended Solids	7D Conc	18	30.50
07/15/08	Limit	00530	Suspended Solids	7D loading	14	26.92