



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Notice of Violation  
Wood County  
Perrysburg Estates MHP WWTP  
Ohio EPA Permit No. 2PY00014  
NPDES Permit No. OH0102687

January 7, 2009

Mr. Bill Thomas  
The Choice Group  
755 West Big Beaver Road, Suite 1275  
Troy, Michigan 48084

Dear Mr. Thomas:

The National Pollutant Discharge Elimination System (NPDES) permit issued to The Choice Group dba Perrysburg Estates Mobile Home Park, has a requirement in Part I,C - Schedule of Compliance, Item 1 for the submittal of a sewer system evaluation survey (SSES) to this office no later than December 1, 2008. This requirement was also in the previous NPDES permit issued for this mobile home park (MHP).

In addition, Part I, C - Schedule of Compliance, Item 2 requires that the bypass outlet from the older treatment plant be totally eliminated with verification of the elimination to be submitted to this office no later than October 1, 2008.

Please inform this office in writing, within 10 days of receipt of this letter, as to how you plan to rectify these violations of the NPDES permit for this MHP. Please be advised that if these terms and conditions of the schedule of compliance continue to be ignored, enforcement action will be initiated pursuant to Ohio Revised Code, Chapter 6111 in order achieve compliance.

If you have any questions, please feel free to contact this office.

Cordially,

Patricia A. Tebbe, P.E.  
Division of Surface Water

/csl

pc: Follow-up file  
Dan Wickard, NWWSD  
DSW-NWDO file