



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Notice of Violation
Wood County
City of Perrysburg WWTP
Ohio EPA Permit No. 2PD00002*ID
NPDES Permit No. OH021008

February 17, 2011

Mr. Gary Haydel, Superintendent
City of Perrysburg WWTP
210 West Indiana Avenue
Perrysburg, Ohio 43551

Dear Mr. Haydel:

A review of your self-monitoring reports for the referenced facility covering the months of December 2008, through December 2010, indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are enclosed on a separate sheet.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in Part III - General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://www.epa.state.oh.us/ocapp/ocapp.html> or by calling (614) 644-3469.

If you have any questions, please feel free to contact me at (419) 373-3016.

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

//lr

~~PC: DSW: NWDO: File~~

City of Perrysburg WWTP
Violations 12/1/2008 through 12/31/2010

date	station	viotype	rptcode	parameter	lmttype	limit	rptvalue
12/08/08	001	Limit	00665	Phosphorus	7D Qty	31	31.4
09/01/09	001	Limit	00665	Phosphorus	30D Conc	1.0	1.3
09/08/09	001	Limit	00665	Phosphorus	7D Conc	1.5	1.6
08/01/10	001	Limit	00665	Phosphorus	7D Qty	31	32.4
08/01/10	001	Limit	00665	Phosphorus	30D Qty	20	20.2
08/01/10	001	Limit	00665	Phosphorus	7D Conc	1.5	2.2
08/01/10	001	Limit	00665	Phosphorus	30D Conc	1.0	1.2
11/08/10	001	Limit	00665	Phosphorus	7D Conc	1.5	1.6