



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Wood County
Southview Estates MHP
Ohio EPA Permit No. 2PY000010
NPDES Permit No. OH0095419

January 7, 2009

Mr. Robert Maurer
Southview Estates MHP
Greenbriar Realty
224 E. Wooster St.
Bowling Green, OH 43402

Dear Mr. Maurer:

A review of your self-monitoring reports for the referenced facility covering the months of January 2006 through November 2008 indicate violations of the conditions of your NPDES permit. The specific instances of limit violations are enclosed in a separate table.

Other noncompliance violations of the NPDES permit include:

Part I,C - Schedule of Compliance:

a. detail plans for sewer system improvements were to be submitted no later than July 1, 2007

Part I, C - Schedule of Compliance of the NPDES permit requires that you secure a sanitary sewer connection to the available municipal sewer and eliminate the discharge no later than May 1, 2009. You will need to contact the City of Perrysburg for their requirements to connect to the sanitary sewer and submit a Permit to Install to Ohio EPA for that connection.

Please be aware that the NPDES permit for the Southview Estates MHP expires on June 30, 2009. Please be advised that failure to comply with the requirements of the NPDES permit will subject you to escalated enforcement action to achieve compliance.

If you have any questions, please feel free to contact this office.

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water
/csl

Enclosure

pc: 'DSW-NWDO file >
Gary Haydel, City of Perrysburg
Mike Carson

Southview Estates MHP
 January 1, 2006 through November 30, 2008
 limit violations

date	station	viotype	rptcode	parameter	lmttype	limit	rptvalue
June 2006							
20-Jun-06	001	Limit	50060	Chlorine	1D Conc	0.019	1.
August 2006							
1-Aug-06	001	Limit	00610	Ammonia	30D Conc	1.5	1.87
10-Aug-06	001	Limit	00610	Ammonia	1D Conc	2.3	6.6
February 2008							
10-Feb-08	001	Limit	80082	CBOD 5 day	1D Conc	15	16.
March 2008							
1-Mar-08	001	Limit	00530	Suspended Solids	1D Conc	18	22.
1-Mar-08	001	Limit	80082	CBOD 5 day	30D Conc	10	11.
1-Mar-08	001	Limit	00530	Suspended Solids	30D Conc	12	16.5
10-Mar-08	001	Limit	00530	Suspended Solids	1D Conc	18	24.
April 2008							
1-Apr-08	001	Limit	80082	CBOD 5 day	30D Conc	10	11.5
November 2008							
16-Nov-08	001	Limit	00530	Suspended Solids	1D Conc	18	32.