



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Wood County
Troy Energy, LLC
Industrial

January 2, 2008

Mr. Joseph Finocchiaro
Sr Environmental Engineer
Troy Energy, LLC
1044 North 115 th Street, Suite 400
Omaha, Nebraska 68154

Dear Mr. Finocchiaro:

On November 15, 2007, a compliance inspection was conducted of the Troy Energy, LLC, Luckey, OH facilities. The inspection was conducted of all areas of the plant including the 001 outfall. At the time of the inspection there was no discharge at the 001 outfall.

Troy Energy, LLC is operating under a National Pollutant Discharge Elimination System (NPDES) permit which expires December 31, 2007. This permit is in the process of being renewed and you will receive a draft copy of the permit in the near future. Please carefully review this permit and if you have any comments, make them during the 30 day comment period. All comments will be addressed before the permit is issued final.

Troy Energy, LLC, Luckey Plant, produces electrical power for peaking services. Fuel used to generate the electricity is normally natural gas but there is a supply of No. 2 oil as a backup fuel on site. Surface storm water from the facility is directed to an aerated detention pond before discharge. Storm water from the containment area around the fuel oil storage tanks and the chemical containment area discharges through an oil/water separator before flowing to the detention pond.

All areas around the facility appeared clean with no staining or indications of spills. A review of submitted monitoring reports shows no violations from this facility.

If you have any questions, please feel free to contact me at (419) 373-3016.

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/lb

pc: Greg Ball, Luckey facility
~~DSW-NWDO file~~