



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Wood County
Village of Weston WWTP
Ohio EPA Permit No. 2PB00011
NPDES Permit No. OH0020681

June 5, 2008

Mr. Jerry Greiner, Executive Director
Northwestern Water and Sewer District
PO Box 348
Bowling Green, OH 43402

Dear Mr. Greiner:

A review of the self-monitoring reports for the Village of Weston wastewater treatment plant (WWTP) covering the months of October 2006 through March, 2008 indicates violations of the conditions of your National Pollutant Discharge Elimination System (NPDES) permit. The specific instances of noncompliance are enclosed.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in Part III - General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U.S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

Please inform this office in writing, within 10 days of receipt of this letter, as to the description of the actions taken or proposed to prevent further violations of this nature. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions, please feel free to contact this office.

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/lb

pc:

DSW-NWDO file

Weston WWTP
Limit Violations for the Period of 10/1/06 through 4/30/08

date	station	rptcode	parameter	type	limit	reported
October 2006						
10/01/06	001	00530	Suspended Solids	7D Conc	40	228
10/01/06	001	00530	Suspended Solids	30D Conc	25	112.2
10/01/06	001	00530	Suspended Solids	7D Qty	42.4	150.7
10/01/06	001	00530	Suspended Solids	30D Qty	26.5	71.72
10/08/06	001	00530	Suspended Solids	7D Conc	40	92
10/08/06	001	00530	Suspended Solids	7D Qty	42.4	46.3
10/19/06	001	00300	Dissolved Oxygen	1D Conc	6.0	5
10/22/06	001	00530	Suspended Solids	7D Conc	40	62
10/31/06	001	00300	Dissolved Oxygen	1D Conc	6.0	5.3
November 2006						
11/01/06	001	00530	Suspended Solids	7D Conc	40	43
April 2007						
04/01/07	001	00530	Suspended Solids	30D Conc	12	16.1
04/22/07	001	00530	Suspended Solids	7D Conc	18	28.2
May 2007						
05/01/07	001	00530	Suspended Solids	30D Conc	12	13.9
05/01/07	001	00530	Suspended Solids	30D Qty	12.7	14.1
05/01/07	001	00530	Suspended Solids	7D Qty	19.1	23.3
05/08/07	001	00530	Suspended Solids	7D Conc	18	19.5
05/08/07	001	00530	Suspended Solids	7D Qty	19.1	19.2
August 2007						
08/20/07	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8
December 2007						
12/01/07	001	00530	Suspended Solids	30D Conc	12	12.5
12/01/07	001	00530	Suspended Solids	30D Qty	12.7	14.9
12/08/07	001	00530	Suspended Solids	7D Conc	18	23.2
12/08/07	001	00530	Suspended Solids	7D Qty	19.1	33.5
January 2008						
01/01/08	001	00530	Suspended Solids	30D Qty	12.7	12.9
01/01/08	001	00530	Suspended Solids	30D Conc	12	12.1
01/08/08	001	00530	Suspended Solids	7D Conc	18	27.2
01/08/08	001	00530	Suspended Solids	7D Qty	19.1	36.2
February 2008						
02/01/08	001	00530	Suspended Solids	30D Conc	12	20.1
02/01/08	001	00530	Suspended Solids	7D Conc	18	54
02/01/08	001	00530	Suspended Solids	30D Qty	12.7	25.4
02/01/08	001	00530	Suspended Solids	7D Qty	19.1	75.5
02/01/08	001	80082	CBOD 5 day	7D Conc	15	15.5
02/01/08	001	80082	CBOD 5 day	7D Qty	15.9	21.6
March 2008						
03/15/08	001	00530	Suspended Solids	7D Conc	18	23.5
03/15/08	001	00530	Suspended Solids	7D Qty	19.1	25.3