



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

Re: Wyandot County  
County Environmental  
NPDES Permit

October 26, 2010

Mr. Chris Jaquet, Environmental Manager  
County Environmental of Wyandot  
11164 County Road 4  
Carey, Ohio 43316

Dear Mr. Jaquet:

This will acknowledge our October 15, 2010, compliance inspection at your Wyandot County facility. This facility is located at 11164 County Road 4, Carey, Ohio. This inspection was conducted as part of the renewal process of the facility's National Pollutant Discharge Elimination System (NPDES) permit No. 2IN00121\*CD (OH0102482).

At the time of the inspection, Outfalls 003, 004 and 012 were not discharging. A clear discharge was noted at Outfall 009. When a discharge occurs from any of these outfalls, it must be sampled in accordance with this NPDES permit.

We are in the process of renewing your existing NPDES permit which expires on January 31, 2011. In the event that you do not receive your renewed NPDES permit by January 31, 2011, please continue to operate your facility per your expired permit. Our review of your Discharge Monitoring Reports (1/2009 to 9/2010) for this facility indicated two effluent violations. Please refer to the enclosed violation table.

A completed inspection report is included for your review. If you have any questions or comments, please call me at 419-373-3021.

Sincerely,

Jason Ko  
Division of Surface Water

/llr

cc: DSW-NWDO File

# NPDES COMPLIANCE INSPECTION REPORT

## Section A: National Data System Coding

Permit #	NPDES	Yr/Mo/Day	Inspection Type	Inspector	FacType
2IN00121	OH0102482	2010/10/15	C	S	I

## Section B: Facility Data

Name and Location of Facility Inspected  County Environmental of Wyandot 11164 County Road 4 Carey, OH 43316	Entry Time	Permit Effective Date
	9:15 A.M.	2/1/2006
	Exit Time	Permit Expiration Date
	10:15 A.M.	1/31/2011

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Mr. John Niederkoehr, Operator	(419) 396-3581

Name, Address and Title of Responsible Official	Phone Number
Mr. Chris Jaquet, Environmental Manager County Environmental of Wyandot 11164 County Road 4 Carey, OH 43316	(734) 652-2734

## Section C: Areas Evaluated During Inspection


(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

S Permit	-- Flow Measurement	-- Pretreatment
N Records/Reports	-- Laboratory	-- Compliance Schedules
S Operations & Maintenance	S Effluent	S Self-Monitoring Program
S Facility Site Review	-- Sludge Storage/Disposal	- Other

## Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

- \* Outfalls 003, 004 & 012 were not discharging
- \* Outfall 009 had a clear discharge (stormwater runoff & dewatering the borrow pit)
- \* Current NPDES permit will expire on 1/31/2011 & sampling per the NPDES permit
- \* A review of DMR (1/2009 to 9/2010) indicated two effluent violations

  
 Jason Ko, Ohio EPA, Northwest District Office  
 Name(s) and Signature(s) of Inspector(s) Date 10/28/10

  
 Elizabeth A. Wick, P.E., Ohio EPA, Northwest District Office  
 Name and Signature of Reviewer Date 10/22/10

Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2IN00121*CD	May 2010	009	00530	Total Suspended Solids	1D Conc	45	74.	5/3/2010
2IN00121*CD	May 2010	009	00530	Total Suspended Solids	30D Conc	30	74.	5/1/2010