



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

File: Preble Co
Preble Sew. Dist #2
Sewerage
1PG00092

April 5, 2011

CERTIFIED MAIL

John S. Jones, Facilities Manager
Preble County Sewer District #2
4239 US Rt. 127 North
Eaton, Ohio 45320

RE: Preble County Sewer District #2 WWTP Notice of Violation (NOV)

Dear Mr. Jones:

We have received your self-monitoring report covering the months of September 2009 through February 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies were as follows:

Numerical Violations

<u>Date</u>	<u>Station</u>	<u>Parameter</u>	<u>Code</u>	<u>Permit Limit</u>	<u>Reported</u>
1/1/10	001	Ammonia	00610	0.1 kg/D 30D Qty.	0.19565 kg/D
1/1/10	001	TSS	00530	0.7 kg/D 30D Qty.	1.01211 kg/D
1/15/10	001	Ammonia	00610	0.2 kg/D 7D Qty.	0.3499 kg/D
1/15/10	001	TSS	00530	1.0 kg/D 7D Qty.	1.01211 kg/D
3/1/10	001	TSS	00530	0.7 kg/D 30D Qty.	0.85844 kg/D
3/1/10	001	CBOD5	80082	0.6 kg/D 30D Qty.	1.00151 kg/D
3/1/10	001	Ammonia	00610	0.1 kg/D 30D Qty.	0.24305 kg/D
3/15/10	001	CBOD5	80082	0.9 kg/D 7D Qty.	1.00151 kg/D
3/15/10	001	Ammonia	00610	0.2 kg/D 7D Qty.	0.38916 kg/D
5/1/10	001	Ammonia	00610	0.1 kg/D 30D Qty.	0.12581 kg/D
5/1/10	001	TSS	00530	0.7 kg/D 30D Qty.	0.73391 kg/D
6/1/10	001	TSS	00530	0.7 kg/D 30D Qty.	1.00832 kg/D
6/8/10	001	TSS	00530	1.0 kg/D 7D Qty.	1.00832 kg/D
2/1/11	001	TSS	00530	0.7 kg/D 30D Qty.	0.70401 kg/D
2/1/11	001	CBOD5	80082	0.6 kg/D 30D Qty.	0.70552 kg/D

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Ohio EPA has received your reports for all the above noted violations, with the exception of the January 2010 violations. Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the January violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions regarding the above, please contact me at this office.

Respectfully,



Maureen M. Ware
Division of Surface Water

MW/rb

cc: Preble County Health Dept.

4E9D TR44 2000 0050 E002 7003 0500 0002 4411 0634

U.S. Postal Service™	
CERTIFIED MAIL™ RECEIPT	
<i>(Domestic Mail Only; No Insurance Coverage Provided)</i>	
For delivery information visit our website at www.usps.com	
OFFICIAL USE	
Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
	Postmark Here 4/5/11
JOHN S JONES, FACILITIES MANAGER PREBLE COUNTY SEWER DISTRICT #2 4239 US RT. 127 NORTH EATON, OHIO 45320	
PS Form 3800, June 2002	See Reverse for Instructions