



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 4, 2007

RE: JOLLY TIME MOBILE HOME PARK
RAVENNA TOWNSHIP
PORTAGE COUNTY
3PV00085*DX

Mr. Steve Korpita, Owner
Jolly Time Mobile Home Park
3525 State Route 183
Rootstown, OH 44272

Dear Mr. Korpita:

On August 31, 2007, this writer conducted an inspection of your wastewater treatment works located at 5365 State Route 14 in Ravenna. The purpose of the inspection was to gather information necessary to renew the above referenced National Pollutant Discharge Elimination System (NPDES) permit which expires on April 30, 2008. A compliance evaluation has also been performed.

The sewage treatment plant serves a small mobile home park and the bait and tackle shop. It consists of a 630-gallon trash trap, followed by a 2,300-gpd aeration plant, dosing chamber, 190 square feet of surface sand filters equally divided into two beds, and a chlorination/dechlorination chamber.

At the time of the inspection the following was noted concerning the plant:

- The color in the aeration tank was a light brown in color.
- There was only minor overflow into the weir trough in the clarifier.
- The clarifier did contain a small amount of floating solids.
- The sand filters were clean and raked level. Of concern was the large grain size of the sand in the filter. It appears to be larger than what would have been approved.
- No flow was observed from the plant at the time of the inspection.

Your compliance history for the time period of January 2005 through July 2007 revealed the following numeric violations of your NPDES permit:

Numeric Violations

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	16.	8/1/2005
001	31616	Fecal Coliform	30D Conc	200	930.	8/1/2005
001	31616	Fecal Coliform	7D Conc	400	930.	8/1/2005
001	00530	Total Suspended Solids	30D Conc	12	13.	6/1/2005
001	31616	Fecal Coliform	30D Conc	200	580.	6/1/2005
001	31616	Fecal Coliform	7D Conc	400	580.	6/8/2005
001	80082	CBOD 5 day	30D Conc	10	23.	6/1/2005
001	80082	CBOD 5 day	7D Conc	15	23.	6/8/2005
001	00300	Dissolved Oxygen	1D Conc	6.0	2.7	6/9/2005

Mr. Steve Korpita
 Jolly Time Mobile Home Park
 September 4, 2007
 Page 2

001	00530	Total Suspended Solids	30D Conc	12	14.	12/1/2005
001	80082	CBOD 5 day	30D Conc	10	28.	12/1/2005
001	80082	CBOD 5 day	7D Conc	15	28.	12/8/2005
001	80082	CBOD 5 day	30D Conc	10	26.	3/1/2007
001	80082	CBOD 5 day	7D Conc	15	26.	3/15/2007
001	00300	Dissolved Oxygen	1D Conc	6.0	3.1	3/15/2007
001	00530	Total Suspended Solids	30D Conc	12	14.	6/1/2006
001	31616	Fecal Coliform	30D Conc	200	3200.	6/1/2006
001	31616	Fecal Coliform	7D Conc	400	3200.	6/1/2006
001	80082	CBOD 5 day	30D Conc	10	23.	6/1/2006
001	80082	CBOD 5 day	7D Conc	15	23.	6/1/2006

Frequency Violations

Violation Date	Station	Reporting Code	Parameter	Sample Frequency	Expected	Reported
1/1/2006	001	00083	Color, Severity	1/Week	1	0
1/8/2006	001	00083	Color, Severity	1/Week	1	0
1/15/2006	001	00083	Color, Severity	1/Week	1	0
1/22/2006	001	00083	Color, Severity	1/Week	1	0
1/1/2006	001	01330	Odor, Severity	1/Week	1	0
1/8/2006	001	01330	Odor, Severity	1/Week	1	0
1/15/2006	001	01330	Odor, Severity	1/Week	1	0
1/22/2006	001	01330	Odor, Severity	1/Week	1	0
1/1/2006	001	01350	Turbidity, Severity	1/Week	1	0
1/8/2006	001	01350	Turbidity, Severity	1/Week	1	0
1/15/2006	001	01350	Turbidity, Severity	1/Week	1	0
1/22/2006	001	01350	Turbidity, Severity	1/Week	1	0

For each of the above violations not reported in accordance with Part III, Section 12 of the NPDES permit, you have incurred additional separate violations.

Your NPDES permit will be drafted and sent out for public notice and comment in the near future. We advise you to read the conditions in Part II, as there will be changes. If you should have any questions, feel free to contact this writer at (330) 963-1136.

Sincerely,



Philip P. Rhodes, P. E.
 Environmental Engineer
 Division of Surface Water

PPR/mt

File: Semi-Public, Jolly Time Mobile Home Park