



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Konecki, Director

August 6, 2010

RE: JOLLY TIME MOBILE HOME PARK
PERMIT NO. 3PV00085
PORTAGE COUNTY
RAVENNA TOWNSHIP

Mr. Steve Korpita, Owner
Jolly Time Mobile Home Park
3525 State Route 183
Rootstown, Ohio 44272

Dear Mr. Korpita:

On July 20, 2010, an inspection of the above referenced facility's wastewater treatment system was conducted. No one was present during the inspection. The purpose of the inspection was to evaluate the operation and maintenance of the treatment system along with the facility's compliance status with respect to the terms and conditions of the above referenced National Pollutant Discharge Elimination System (NPDES) permit.

During the inspection, the following items were noted:

1. The design flow of the extended aeration wastewater treatment plant is 2,300 gallons per day.
2. The blowers were not running therefore the skimmer and sludge return line could not be evaluated.
3. The weirs and the sidewalls in the settling tank were free of scum build-up.
4. Scum build-up was present behind the baffle in the settling tank. This should be removed and properly disposed.
5. The surface sand filter beds had minimal vegetation growing in them. The beds appeared to be well maintained.
6. The chlorination/dechlorination units were not evaluated due to the vault grating being locked. However the effluent in the vault was clear. The bottom of the vault could be observed.
7. The effluent was clear. No visual impact to the receiving area was noted.
8. There appears to be no record of waste sludge hauling (Station 3PV00085588). Sludge should be wasted and hauled as necessary to ensure that the right balance of biological activity is maintained within the treatment system.

This office has recently reviewed your self-monitoring reports covering the period August 1, 2008 through June 30, 2010 for the referenced facility. Our review indicates violations of the terms and conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Mr. Steve Korpita
Jolly Time Mobile Home Park
August 9, 2010
Page 2

Limit Violations

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00300	Dissolved Oxygen	1D Conc	6.0	4.5	8/6/2008
001	00530	Total Suspended Solids	30D Conc	12	18.	12/1/2008
001	00530	Total Suspended Solids	7D Conc	18	28.	12/8/2008
001	00530	Total Suspended Solids	30D Conc	12	21.	6/1/2010
001	00530	Total Suspended Solids	7D Conc	18	21.	6/8/2010

No frequency or code violations were noted.

This office is in receipt of your July 23, 2010 e-mail explaining the cause of the total suspended solids permit violation. No further information is required.

Please be advised that such instances of noncompliance may be cause for enforcement actions pursuant to the Ohio Revised Code, Chapter 6111.

Should you have any comments or questions concerning this letter, please feel free to call me at (330) 963-1143.

Respectfully,



Michael W. Stevens
Environmental Engineer
Division of Surface Water

MWS/mt