



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 17, 2009

RE: PORTAGE COUNTY
RANDOLPH TWP.
SAINT JOSEPH PARISH
2643 WATERLOO ROAD

Father Edward R. Wiczorek
Saint Joseph Parish
2643 Waterloo Road
Mogadore, Ohio 44260

Dear Father Wiczorek:

A site inspection of the Saint Joseph Parish sewage treatment system was conducted on February 11, 2009. At the time of my inspection the plant was in good condition and producing a clear effluent.

A review of monthly operating report data for your Ohio EPA permitted discharge (#3PR00263*BD) for the time period January 2007 through November 2008 indicates the following effluent violations:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2007	Total Suspended Solids	Maximum Concentration	18	19	2/28/2007
February 2007	Total Suspended Solids	Monthly Concentration	12	14.75	2/1/2007
August 2007	Total Suspended Solids	Maximum Concentration	18	20	8/15/2007
August 2007	Total Suspended Solids	Monthly Concentration	12	12.75	8/1/2007
July 2007	Chlorine	Maximum Concentration	0.038	0.1	7/30/2007

Effluent flow values for the plant remain below the design capacity of 15,000 gallons per day.

Statistic	Gallons Per Day
Average	2117
Median	2350
Maximum	3350

Should you have further questions, please call me at (330) 963-1134.

Sincerely,

William J. Zawiski
Environmental Scientist
Division of Surface Water

WJZ/mt