



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

March 4, 2011

RE: PORTAGE COUNTY
SUFFIELD TOWNSHIP
PARADISE LAKE COUNTY CLUB
1900 RANDOLPH ROAD
NPDES #3PR00496

Mr. Thomas Ambach
1900 Randolph Road
Mogadore, OH 44260

Dear Mr. Ambach:

A permit compliance inspection was conducted at the above location on March 2, 2011. The clubhouse was closed at the time we were at the site. A permit to discharge was issued on October 14, 2009 to cover the wastewater treatment plant at the site.

At the time of our inspection the plant was in good operational condition. The sludge return was a little light in color indicating a lower facility usage. Review of flow monitoring indicates an average effluent flow volume of 195 gallons per day (gpd), well below the design flow of 3,000 gpd.

A review of our database indicated the following permit limit violations during the time period November 2009 through January 2011:

Table with 7 columns: Reporting Period, Station, Parameter, Limit Type, Limit (mg/l), Reported Value, Violation Date. Rows include December 2009 (CBOD 5 day) and June 2010 (Chlorine).

Should you have further questions, please call me at (330) 963-1134.

Sincerely,

Handwritten signature of William J. Zawiski

William J. Zawiski
Environmental Supervisor
Division of Surface Water

WJZ/mt

pc: Mr. Rich Lashley, Portage County Health Department