



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 14, 2009

RE: GOODYEAR TIRE & RUBBER
EMPLOYEE PARK
PERMIT NO. 3PR00241
PORTAGE COUNTY
SUFFIELD TOWNSHIP

Mr. Gregory W. Stallings
Environmental Engineer
Good Year Tire & Rubber Company
1144 E. Market Street, Dept. 480-B
Akron, Ohio 44316

Dear Mr. Stallings:

On March 10, 2009, an inspection of the above referenced facility's wastewater treatment system was conducted. The purpose of the inspection was to evaluate the operation and maintenance of the treatment system along the facility's compliance status with respect to the terms and conditions of the above referenced National Pollutant Discharge Elimination System (NPDES) permit.

During the inspection, the following items were noted:

1. The plant design of the wastewater treatment system is 5,000 gpd.
2. The plant was shut down.
3. No discharge has been reported since September 2007.

Per a phone conversation with Mr. Rick Laney on March 13, 2009, it is the Agency's understanding that the property is up for sale. Please note that Goodyear Tire & Rubber should continue submitting the monthly discharge monitoring report until the park has been sold. A permit transfer form will need to be completed once the park has been sold.

This office has recently reviewed your self-monitoring reports covering the period May 1, 2006 through March 31, 2009 for the referenced facility. Our review indicates violations of the terms and conditions of your NPDES permit. The specific instances of non-compliance are as follows:

Frequency Violations

Station	Reporting Code	Parameter	Sample Frequency	Expected	Reported	Violation Date
001	00665	Phosphorus, Total (P)	1/Month	1	0	05/01/2006
001	50060	Chlorine, Total Residue	1/2Weeks	1	0	08/15/2006
001	50060	Chlorine, Total Residue	1/2Weeks	1	0	05/15/2007

Mr. Gregory W. Stallings
 Good Year Tire & Rubber Company
 April 14, 2009
 Page 2

Station	Reporting Code	Parameter	Sample Frequency	Expected	Reported	Violation Date
001	00665	Phosphorus, Total (P)	1/Month	1	0	06/01/2007
001	50060	Chlorine, Total Residue	1/2Weeks	1	0	06/15/2007
001	50060	Chlorine, Total Residue	1/2Weeks	1	0	07/15/2007
001	00010	Water Temperature	1/Week	1	0	08/01/2007
001	00010	Water Temperature	1/Week	1	0	08/15/2007
001	50060	Chlorine, Total Residue	1/2Weeks	1	0	08/15/2007
001	00010	Water Temperature	1/Week	1	0	08/22/2007
001	50060	Chlorine, Total Residue	1/2Weeks	1	0	09/15/2007

Limit Violations

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.04	7/1/2006
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	4.79	8/1/2006
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.5	4.79	8/8/2006
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	4.28	9/1/2006
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.019	.01944	9/1/2006
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	4.28	9/7/2006
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	4.53	4/1/2007
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	4.5	4.53	4/24/2007
001	50060	Chlorine, Total Residue	1D Conc	0.019	.19	9/6/2007

Please be advised that such instances of non-compliance may be cause for enforcement actions pursuant to the Ohio Revised Code, Chapter 6111.

Should you have any comments or questions concerning this letter, please feel free to call me at (330) 963-1143.

Respectfully,



Michael W. Stevens
 Environmental Engineer
 Division of Surface Water

MWS/mt