



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 30, 2008

RE: PORTAGE COUNTY  
MANTUA  
YOGI BEAR'S JELLYSTONE PARK  
PERMIT #3PR00090

Mr. Jim Compeli  
Yogi Bear's Jellystone Park  
3392 State Route 82  
Mantua, OH 44255

Dear Mr. Compeli:

This office conducted an inspection of the sewage treatment plant serving your facility on April 23, 2008. At the time of my inspection, it appeared that the plant was producing an acceptable effluent. It is noted that some maintenance work needs to be completed on the tertiary sand filter beds.

The discharge permit for the site expired on March 31, 2008. A renewal application has not yet been received. Please be advised that you are currently discharging wastewater to "waters of the state" without a valid permit. This is in violation of Ohio Revised Code Chapter 6111. Please contact this office to discuss resolution of the violation.

A review of monthly operating reports was conducted for the time period January 1, 2007, through March 31, 2008. During this time period the average daily flow from the facility was 7,000 gallons per day with a maximum flow of 26,000 gallons per day. The system is designed for an average daily flow of 30,000 gallons per day. The following violations were identified by our computer screening program:


Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
April 2007	Dissolved Oxygen	1D Conc	5.0	4.8	4/3/2007
August 2007	pH	1D Conc	6.5	4.4	8/7/2007
August 2007	pH	1D Conc	6.5	5.7	8/14/2007
August 2007	pH	1D Conc	6.5	3.6	8/21/2007
August 2007	Dissolved Oxygen	1D Conc	5.0	3.7	8/7/2007
August 2007	Dissolved Oxygen	1D Conc	5.0	2.2	8/14/2007
August 2007	Dissolved Oxygen	1D Conc	5.0	3.5	8/21/2007
October 2007	pH	1D Conc	6.5	6.	10/2/2007
June 2007	Nitrogen, Ammonia (NH3)	30D Conc	2.0	10.125	6/1/2007
June 2007	Nitrogen, Ammonia (NH3)	7D Conc	3.0	9.05	6/1/2007
June 2007	Nitrogen, Ammonia (NH3)	7D Conc	3.0	11.2	6/15/2007
June 2007	Nitrogen, Ammonia (NH3)	7D Qty	0.3	.30829	6/1/2007
June 2007	pH	1D Conc	6.5	4.8	6/5/2007
June 2007	pH	1D Conc	6.5	5.7	6/12/2007

Mr. Jim Compeli  
Yogi Bear's Jellystone Park  
April 30, 2008  
Page 2

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2007	pH	1D Conc	6.5	5.3	6/19/2007
June 2007	pH	1D Conc	6.5	5.3	6/26/2007
June 2007	Dissolved Oxygen	1D Conc	5.0	3.2	6/19/2007
June 2007	Dissolved Oxygen	1D Conc	5.0	3.3	6/26/2007
July 2007	Nitrogen, Ammonia (NH3)	30D Conc	2.0	9.15667	7/1/2007
July 2007	Nitrogen, Ammonia (NH3)	7D Conc	3.0	23.75	7/1/2007
July 2007	Nitrogen, Ammonia (NH3)	30D Qty	0.2	.47189	7/1/2007
July 2007	Nitrogen, Ammonia (NH3)	7D Qty	0.3	1.25851	7/1/2007
July 2007	pH	1D Conc	6.5	6.1	7/3/2007
July 2007	pH	1D Conc	6.5	6.	7/10/2007
July 2007	pH	1D Conc	6.5	6.3	7/17/2007
July 2007	pH	1D Conc	6.5	5.6	7/25/2007
July 2007	pH	1D Conc	6.5	4.9	7/31/2007
July 2007	Dissolved Oxygen	1D Conc	5.0	3.4	7/3/2007
July 2007	Dissolved Oxygen	1D Conc	5.0	3.3	7/10/2007
July 2007	Dissolved Oxygen	1D Conc	5.0	1.6	7/17/2007
July 2007	Dissolved Oxygen	1D Conc	5.0	3.2	7/25/2007
July 2007	Dissolved Oxygen	1D Conc	5.0	2.7	7/31/2007

Should you have any questions, please contact me at (330) 963-1134.

Sincerely,



William J. Zawiski  
Environmental Scientist  
Division of Surface Water

WJZ/mt