



**Environmental
Protection Agency**

John Kasich, Governor
Tim Wolfe, Lt. Governor
Chris Mitchell, Director

May 3, 2010

RE: PORTAGE COUNTY
MANTUA TOWNSHIP
MANTUA CENTER SCHOOL
11741 MANTUA CENTER ROAD
PERMIT # 3PT00107*BD

Mantua Township Trustees
Marie Stehli, Clerk
3898 Winchell Rd
Mantua, Ohio 44255

Dear Trustees:

This letter will document an April 30, 2010 inspection at the above site. The inspection was conducted by the Portage County Health Department and this writer.

The existing sewage treatment plant has a hydraulic capacity of 4,000 gallons per day. Treatment at the plant consists of extended aeration, tertiary filtration, and chlorination.

It appears that the plant is used infrequently and has a very low flow. Monthly operating reports were examined for the timeframe from January 2009 through March 2010. There were no noted permit violations as there was also no discharge volume reported during this time period. Your permit requires sampling when discharging.

Some vegetation was noted in the sand filters. Maintenance of these treatment units requires them to be free of rooted vegetation.

Should you have further questions, please call me at (330) 963-1134.

Sincerely,

William J. Zawiski
Environmental Scientist
Division of Surface Water

WJZ/mt

cc: Rich Lashley, Portage County Health Department