



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 31, 2011

**RE: STARK COUNTY
BETHLEHEM TOWNSHIP
BETH MHP
6000 BETH AVENUE
NPDES #3PV00115**

Mr. Robert Miller
Beth Mobile Home Park
6000 Beth Avenue SW
Canton, OH 44706

Dear Mr. Miller:

On January 27, 2011 a compliance evaluation inspection (CEI) was conducted by this writer of the wastewater treatment system serving the above referenced facility.

At the time of the inspection, the mixed liquor in the aeration tank had a dark brown color, indicative of a properly operating biological system. The final clarifier was producing a clear effluent. The surface sand filter was in good condition and the treatment system was producing a clear effluent that appeared to be of satisfactory quality.

A review of your Discharge Monitoring Reports (DMRs) covering the period December 2008 through December 2010 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
January 2009	001	Nitrogen, Ammonia (NH3)	30D Conc	3.0	3.47	1/1/2009
December 2010	001	Total Suspended Solids	30D Qty	0.68	3.785	12/1/2010
December 2010	001	Total Suspended Solids	7D Qty	1.02	3.785	12/1/2010
December 2010	001	Nitrogen, Ammonia (NH3)	30D Qty	0.170	.18925	12/1/2010
December 2010	001	CBOD 5 day	30D Qty	0.568	18.925	12/1/2010
December 2010	001	CBOD 5 day	7D Qty	0.852	18.925	12/1/2010
May 2010	001	Total Suspended Solids	30D Qty	0.68	3.785	5/1/2010
May 2010	001	Total Suspended Solids	7D Qty	1.02	3.785	5/15/2010
May 2010	001	Nitrogen, Ammonia (NH3)	30D Qty	0.057	.18925	5/1/2010
May 2010	001	Nitrogen, Ammonia (NH3)	7D Qty	0.085	.18925	5/15/2010
May 2010	001	CBOD 5 day	30D Qty	0.568	18.925	5/1/2010
May 2010	001	CBOD 5 day	7D Qty	0.852	18.925	5/15/2010
July 2010	001	Total Suspended Solids	30D Qty	0.68	1.26608	7/1/2010
July 2010	001	Total Suspended Solids	7D Qty	1.02	1.26608	7/1/2010
July 2010	001	CBOD 5 day	30D Qty	0.568	2.02573	7/1/2010
July 2010	001	CBOD 5 day	7D Qty	0.852	2.02573	7/1/2010
June 2009	001	Total Suspended Solids	30D Conc	12	14.	6/1/2009
April 2010	001	CBOD 5 day	30D Conc	10	16.	4/1/2010
April 2010	001	CBOD 5 day	7D Conc	15	16.	4/8/2010

Overall, the results of the inspection were satisfactory.

Mr. Robert Miller
Beth Mobile Home Park
January 31, 2011
Page 2

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely,

A handwritten signature in black ink, appearing to read "Todd Surrena". The signature is fluid and cursive, with a long horizontal stroke extending to the right.

Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/cl

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Beth Mobile Home Park