



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 21, 2007

RE: STARK COUNTY  
SUGAR CREEK TOWNSHIP  
CAMP WANAKE  
9463 MANCHESTER AVE.  
NPDES #3PR00308

Mr. Philip White  
Camp Wanake  
9463 Manchester Ave.  
Beach City, OH 44608

Dear Mr. White:

An inspection of the sewage treatment plant serving Camp Wanake was conducted by this writer on September 18, 2007.

At the time of the inspection, the mixed liquor in the aeration tank had a good color and the contents of the settling tank were clear. There was a significant amount of solids along the effluent weir (See Figure 1).




Figure 1 – Settling tank weir

Mr. Philip White  
Camp Wanake  
September 21, 2007  
Page 2

One surface sand filter bed contained a small amount of vegetation and needs to be cleaned. Overall, the system was in good operation and maintenance condition and appeared to be producing a satisfactory quality effluent.

A review of your monthly operating reports covering the period September 2006 through July 2007 revealed the following effluent violations:

Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2007	001	00530	Total Suspended Solids	30D Conc	12	90.	2/1/2007
February 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	3.0	41.3	2/1/2007
February 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.14	.14069	2/1/2007
February 2007	001	80082	CBOD 5 day	30D Conc	10	24.	2/1/2007
February 2007	001	00530	Total Suspended Solids	7D Conc	18	90.	2/22/2007
February 2007	001	00610	Nitrogen, Ammonia (NH3	7D Conc	4.5	41.3	2/22/2007
February 2007	001	80082	CBOD 5 day	7D Conc	15	24.	2/22/2007

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,



Dean W. Stoll, P.E.  
Environmental Engineer  
Division of Surface Water

DWS/mt

cc: Todd Ascani, Stark County Health Department  
Dave Samsa, Wastewater Services

File: Semi-Public/Camp Wanake