



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 25, 2008

RE: STARK COUNTY  
WASHINGTON TOWNSHIP  
DAIRY KOOL  
NPDES 3PR00196

Mr. Robert Carr  
Dairy Kool  
6050 Union Ave.  
Alliance, OH 44601

Dear Mr. Carr:

On April 23, 2008, this office conducted a compliance evaluation inspection (CEI) of the wastewater treatment plant serving the above referenced facility. Present during the inspection was this writer.

At the time of the inspection, the treatment plant was producing what appeared to be a satisfactory quality effluent. The mixed liquor in the aeration tank had a good color. There was some pin floc noted in the clarifier. The treatment system was producing a clear effluent. All treatment processes were in very good operation and maintenance condition.

A review of your monthly operating reports covering the period September 2006 through March 2008 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
September 2006	001	Chlorine, Total Residu	1D Conc	0.019	.15	9/12/2006
September 2006	001	Chlorine, Total Residu	1D Conc	0.019	.2	9/28/2006

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.  
Environmental Engineer  
Division of Surface Water

DWS/mt

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Dairy Kool