



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 6, 2007

RE: STARK COUNTY
LAWRENCE TOWNSHIP
TOP O HILL MOBILE HOME PARK
4287 MANCHESTER RD.
3PV00099*AD

Mr. Todd Jones
P.O. Box 669
Uniontown, OH 44685

Dear Mr. Jones:

On August 1, 2007, this writer conducted a compliance evaluation inspection at Top O Hill MHP. It was noted that the construction for all upgrades required in the previous National Pollutant Discharge Elimination System (NPDES) permit have been installed. The following observations were made:

- The surface of the clarifier was covered with sludge. There were solids in the weir trough.
- The sludge return and skimmer were returning waste to the head of the plant.
- The sludge holding tank was not being aerated.
- Surface solids accumulated behind the clarifier influent baffle and at the clarifier effluent weir should be removed.

Pictures of the plant were taken for documentation. A review of your compliance with the limitations contained in your NPDES permit 3PV00099, as identified by SWIMS, indicates the following violations for the time period of September 2006 through June 2007:

Numeric violations

Permit No.	Section	Parameter	Limit	Observed	Date
001	31616	Fecal Coliform	30D Conc	1000	1000, 6/1/2007

Frequency Violations

Date	Permit No.	Section	Parameter	Frequency	Count	Limit
5/8/2007	001	00010	Water Temperature	1/Week	1	0
5/15/2007	001	00010	Water Temperature	1/Week	1	0
5/22/2007	001	00010	Water Temperature	1/Week	1	0
5/8/2007	001	00083	Color, Severity	1/Week	1	0
5/15/2007	001	00083	Color, Severity	1/Week	1	0

Mr. Todd Jones
Top O Hill MHP
August 6, 2007
Page 2

Date	Station	Sample ID	Parameter	Frequency	Result	Pass/Fail
5/22/2007	001	00083	Color, Severity	1/Week	1	0
5/8/2007	001	01330	Odor, Severity	1/Week	1	0
5/15/2007	001	01330	Odor, Severity	1/Week	1	0
5/22/2007	001	01330	Odor, Severity	1/Week	1	0
5/8/2007	001	01350	Turbidity, Severity	1/Week	1	0
5/15/2007	001	01350	Turbidity, Severity	1/Week	1	0
5/22/2007	001	01350	Turbidity, Severity	1/Week	1	0

If you should have any questions, feel free to contact this writer at (330) 963-1136.

Sincerely,



Philip P. Rhodes, P.E.
Environmental Engineer
Division of Surface Water

PPR/mt

File: Semi-Public\Top O Hill MHP