



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

November 22, 2010

RE: STARK COUNTY
LAWRENCE TOWNSHIP
TOP O HILL MHP
4287 MANCHESTER AVE.
NPDES #3PV00099

Mr. Todd Jones
Top O Hill MHP
P.O. Box 669
Uniontown, OH 44685

Dear Mr. Jones:

On November 19, 2010 a compliance evaluation inspection (CEI) was conducted by this writer of the wastewater treatment system serving the above referenced facility.

At the time of the inspection, the mixed liquor in the aeration tank had a good brown color. The final clarifier was producing a clear effluent. The surface sand filters were in good condition. The treatment system was producing a clear effluent.

A review of your Discharge Monitoring Reports (DMRs) covering the period January 1, 2009 through October 31, 2010 revealed the following effluent violations:

Reporting Period	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2009	80082	CBOD 5 day	1D Conc	15	12.	2/2/2009
February 2009	80082	CBOD 5 day	7D Conc	10	12.	2/1/2009
February 2009	80082	CBOD 5 day	7D Qty	0.34	.44057	2/1/2009
September 2009	80082	CBOD 5 day	1D Conc	15	5.	9/7/2009
May 2009	80082	CBOD 5 day	1D Conc	15	9.	5/4/2009
November 2009	80082	CBOD 5 day	1D Conc	15	4.2	11/2/2009
August 2009	80082	CBOD 5 day	1D Conc	15	10.	8/3/2009
April 2010	80082	CBOD 5 day	1D Conc	15	8.4	4/13/2010

Mr. Todd Jones
Top O Hill MHP
November 22, 2010
Page 2

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely,

A handwritten signature in cursive script that reads "Todd Surrena".

Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/kw

cc: Stark County Health Department, Attn: Todd Ascani

File: Semi-Public/Top O Hill MHP
Stark Co / Lawrence Township