



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 9, 2007

RE: M&M MOBILE HOME PARK  
3PV00102\*CD  
PORTAGE COUNTY  
RAVENNA TOWNSHIP

Mr. Charles Hunt  
M&M Mobile Home Park  
7353 State Route 14  
Ravenna, OH 44266

Dear Mr. Hunt:

On September 27, 2007, this writer conducted a compliance evaluation inspection of the wastewater treatment plant for the M&M Mobile Home Park. The treatment system consists of:

- Trash trap,
- 11,000-gpd aeration plant,
- 1,024-square-foot surface sand filters,
- 177-square-foot sludge drying beds,
- 2,458-gallon aerated sludge holding tank, and
- 1,500-gallon chlorine contact chamber equipped with dechlorination.

The following is a summary of my inspection observations:

- 1) The plant is being properly aerated.
- 2) The mixed liquor was chocolate brown in color.
- 3) The clarifier surface contained duckweed on the surface.
- 4) The weeds in the sludge drying beds and surface sand filters need pulled.
- 5) Effluent in the chlorine contact tank was clear, but also contained a minor amount of duckweed.
- 6) No flow was observed at the final outfall.

A review of your compliance history as identified by our SWIMS tracking system for the time period of February 2006 through August 2007 revealed the following violations:

Numeric Violations

| Station | Parameter        | Limit Type | Limit | Reported Value | Violation Date |
|---------|------------------|------------|-------|----------------|----------------|
| 001     | CBOD 5 day       | 1D Conc    | 15    | 32             | 2/8/2007       |
| 001     | CBOD 5 day       | 30D Conc   | 10    | 32             | 2/1/2007       |
| 001     | Dissolved Oxygen | 1D Conc    | 6.0   | 5.8            | 2/9/2006       |

Mr. Charles Hunt  
M&M Mobile Home Park  
October 9, 2007  
Page 2

Frequency Violations

| <b>Violation Date</b> | <b>Station</b> | <b>Parameter</b>       | <b>Sample Frequency</b> | <b>Expected</b> | <b>Reported</b> |
|-----------------------|----------------|------------------------|-------------------------|-----------------|-----------------|
| 12/1/2006             | 586            | Sludge Fee Weight      | 1/Year                  | 1               | 0               |
| 12/1/2006             | 588            | Sludge Volume, Gallons | 1/Month                 | 1               | 0               |

Our files do not include the noncompliance notifications that are required as outlined in Part III, Section 12 of the NPDES permit. This is a separate violation of your permit for each event. Please be advised that violations of your NPDES permit may subject you to a possible enforcement action to be initiated by this office in accordance with Ohio Revised Code 6111. If you should have any questions, feel free to contact this writer at (330) 963-1136.

Sincerely,



Philip P. Rhodes, P.E.  
Environmental Engineer  
Division of Surface Water

PPR/mt

File: Semi Public M&M MHP