

**Environmental
Protection Agency**

John E. Kasich **Governor**

Mark DeWine **Lt. Governor**

Scott J. Terry **Director**

July 25, 2011

RE: STARK COUNTY
NIMISHILLEN TOWNSHIP
CARRIAGE HOUSE
9033 COLUMBUS RD.
NPDES #3PR00479

Mr. Michael Ritchie
Robert King
Precision Holdings, LLC
591 Noel Street
Louisville, OH 44641

Dear Mr. Ritchie:

On July 21, 2011, this writer conducted a compliance evaluation inspection of your wastewater treatment plant located at 9033 Columbus Road. Below you will find a summary of visual observations made during the inspection:

- 1) The plant was being properly aerated and the mixed liquor inside the aeration tank exhibited a grayish brown color.
- 2) The sludge and skimmer returns were operating.
- 3) The clarifier was clear, with slight algae growth in the weir trough.
- 4) The surface sand filters were clean and raked level.
- 5) There was no discharge at the time of the inspection.

A review of your discharge monitoring reports (DMRs) covering the period October 2010 through June 2011 revealed the following violations of your NPDES permit:

Numeric Violations

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	Total Suspended Solids	30D Conc	12	44.	6/1/2011
001	Total Suspended Solids	7D Conc	18	44.	6/8/2011
001	Total Suspended Solids	30D Qty	0.23	.24981	6/1/2011

Frequency Violations


Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
001	Chlorine, Total Residu	1/Quarter	1	0	06/01/2011

Mr. Michael Ritchie
Carriage House
July 25, 2011
Page 2

The chlorination/dechlorination chamber has yet to be installed as required by your NPDES permit. Your engineer indicated that the tank is on order, but due to a back-up at the manufacturer, it has not been delivered. Permit to Install No. 798625 was issued to you on December 17, 2010 for the installation of this tank. Seven months is more than enough time to order and install this treatment component. If the current manufacturer cannot provide this tank, then you should contact another manufacturer as your compliance status is being compromised.

Should you have any questions or comments regarding this letter, please feel free to contact this office at (330) 963-1136 or by e-mail at phil.rhodes@epa.state.oh.us.

Sincerely,



Philip P. Rhodes, P.E.
Environmental Specialist II
Division of Surface Water

PPR/mt

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Carriage House