



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor

September 29, 2008

RE: STARK COUNTY Chris Korleski, Director  
NIMISHILLEN TOWNSHIP  
CARRIAGE HOUSE  
9033 COLUMBUS RD.  
NPDES #3PR00479

Mr. Ray Ward  
9033 Columbus Road  
Louisville, OH 44641

Dear Mr. Ward:

On September 25, 2008, this office conducted an inspection of the wastewater treatment plant serving the above referenced facility. Present during the inspection were this writer and Ray Ward, Carriage House Nite Club.

At the time of the inspection, the system was producing what appeared to be a satisfactory quality effluent. The mixed liquor in the aeration tank had a very good color, and the clarifier was producing a clear effluent. The surface sand filters were in good condition.

A review of your discharge monitoring reports (DMRs) covering the period April 2008 through July 2008 revealed the following effluent violation:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2008	001	pH	1D Conc	6.5	5.09	6/9/2008

During the inspection, Mr. Ward indicated that the business may be sold to a new owner. It will be necessary to transfer the NPDES permit to the new owner if the sale takes place. An NPDES transfer form is included with this letter.

The schedule of compliance (Part I,C) in your NPDES permit requires the addition of disinfection facilities to the treatment system. Detail plans were to be submitted to Ohio EPA by August 1, 2008. To date, these plans have not been received by this office. Therefore, you are in noncompliance with your NPDES permit.

You are directed to submit a permit-to-install application with detail plans for the disinfection facilities to this office as soon as practicable.

Should you have any questions or comments regarding this letter, please feel free to contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.  
Environmental Engineer  
Division of Surface Water

DWS/mt

Enclosure: NPDES transfer

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Carriage House