



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 29, 2008

RE: STARK COUNTY
NIMISHILLEN TOWNSHIP
NORTHMARK PROPERTIES
7349 RAVENNA AVE.
NPDES #3PR00468

CERTIFIED MAIL

Mr. Stephen C. Coon
Coon Restoration & Sealants, Inc.
7349 Ravenna Ave. NE
P.O. Box 259
Louisville, OH 44641

Dear Mr. Coon:

On September 25, 2008, this office conducted an inspection of the wastewater treatment system serving the above referenced facility. Present during the inspection was this writer.

The existing sewage treatment system consists of a trash trap followed by a 1,500 gallon per day extended aeration treatment plant, dosing chamber, surface sand filter and chlorine contact tank with a tablet chlorinator and dechlorinator. The system discharges to an unnamed tributary to the East Branch Nimishillen Creek.

At the time of the inspection, the mixed liquor in the aeration tank had a light brown color, indicative of a plant that is organically under loaded. The sludge return was returning clear water. The sides of the clarifier need to be scraped so solids are returned to the aeration tank. Some solids were noted along the effluent weir in the clarifier. The surface sand filters are not equipped with filter sand that meets Ohio EPA specifications. The contents of the chlorine contact tank were clear.

A review of your discharge monitoring reports (DMRs) covering the period October 2007 through August 2008 revealed the following effluent violation:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2008	001	Fecal Coliform	30D Conc	1000	1380	6/1/2008

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS/mt

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Northmark Properties

7006 0150 0001 7110 8593

U.S. Postal Service
CERTIFIED MAIL RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com

7006 0150 0001 7110 8593

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark
Here

Sent To

Street, Apt. No.,
or PO Box No.

City, State, ZIP+4