



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 29, 2008

RE: STARK COUNTY
NIMISHILLEN TOWNSHIP
SPEE-D-FOODS
5875 RAVENNA AVE.
NPDES #3PR00463

Spee-D-Foods
Corporate Office
P.O. Box 358
9817 Cleveland Ave. NW
Greentown, OH 44630

To Whom It May Concern:

On September 25, 2008, this office conducted a compliance evaluation inspection (CEI) of the wastewater treatment system serving the above referenced facility. Present during the inspection was this writer.

The existing sewage treatment system consists of a trash trap followed by a 1,500 gallon per day extended aeration treatment plant which flows by gravity to a surface sand filter, ultraviolet disinfection and an effluent pump station. The system discharges to an unnamed tributary to the East Branch Nimishillen Creek.

At the time of the inspection, the treatment system was producing what appeared to be a satisfactory quality effluent. The mixed liquor in the aeration tank had a good color. Some vegetation was noted in the surface sand filter. The ultraviolet disinfection system has been installed since the last inspection.

A review of your discharge monitoring reports (DMRs) covering the period October 2007 through August 2008 revealed no effluent violations.

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS/mt

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Spee-D-Foods