



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 26, 2007

RE: STARK COUNTY
NIMISHILLEN TOWNSHIP
CANAAN ACRES CHRISTIAN CAMP
NPDES # 3PR00279

Mr. Fred Magnus, Director
Canaan Acres Christian Camp
8020 Nazarene Street
Louisville, OH 44641-9720

Dear Mr. Magnus:

An inspection of the sewage treatment plant serving Canaan Acres Christian Camp was conducted by this writer on September 19, 2007. Present during the inspection were this writer and Fred Magnus, Director, Canaan Acres Christian Camp.

At the time of the inspection, the treatment plant was producing what appeared to be a satisfactory quality effluent. All treatment processes were in good operation and maintenance condition. The mixed liquor in the aeration tank had a light color, as the plant is organically under loaded. The contents of the clarifier were cloudy. The tablet chlorinator and dechlorinator were nearly empty. Mr. Magnus added tablets during the inspection.

A review of your monthly operating reports covering the period August 2006 through July 2007 revealed the following effluent violations.

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2006	001	Nitrogen, Ammonia (NH3)	30D Conc	1.0	9.56	8/1/2006
August 2006	001	Nitrogen, Ammonia (NH3)	7D Conc	1.5	9.56	8/1/2006
August 2006	001	Nitrogen, Ammonia (NH3)	30D Qty	0.053	.32566	8/1/2006
August 2006	001	Nitrogen, Ammonia (NH3)	7D Qty	0.08	.32566	8/1/2006
August 2006	001	Fecal Coliform	30D Conc	1000	2400.	8/1/2006
August 2006	001	Fecal Coliform	7D Conc	2000	2400.	8/1/2006
August 2006	001	CBOD 5 day	30D Conc	10	14.	8/1/2006
August 2006	001	Dissolved Oxygen	1D Conc	6.0	5.2	8/14/2006
September 2006	001	Fecal Coliform	30D Conc	1000	3200.	9/1/2006
September 2006	001	Fecal Coliform	7D Conc	2000	3200.	9/1/2006
October 2006	001	Chlorine, Total Residu	1D Conc	0.019	.1	10/2/2006
February 2007	001	Nitrogen, Ammonia (NH3)	30D Qty	0.016	.03543	2/1/2007
June 2007	001	Fecal Coliform	30D Conc	1000	3400.	6/1/2007
June 2007	001	Fecal Coliform	7D Conc	2000	3400.	6/1/2007

Mr. Fred Magnus, Director
Canaan Acres Christian Camp
September 26, 2007
Page 2

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2007	001	Chlorine, Total Residu	1D Conc	0.019	.05	6/11/2007
July 2007	001	CBOD 5 day	30D Conc	10	24.	7/1/2007
July 2007	001	CBOD 5 day	1D Conc	15	24.	7/2/2007
July 2007	001	Chlorine, Total Residu	1D Conc	0.019	.12	7/16/2007
July 2007	001	Dissolved Oxygen	1D Conc	6.0	4.8	7/16/2007

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,



Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS/mt

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Canaan Acres Christian Camp