



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 25, 2008

RE: STARK COUNTY  
LAKE TOWNSHIP  
CONGRESS LAKE CLUB  
NPDES #3PR00385

Mr. Joseph DeWitt  
Congress Lake Club  
P.O. Box 370  
Hartville, OH 44632

Dear Mr. DeWitt:

On April 23, 2008, this office conducted a compliance evaluation inspection (CEI) of the sewage treatment plant serving Congress Lake Club. Present during the inspection was this writer.

At the time of the inspection, the treatment plant was producing what appeared to be a satisfactory quality effluent. The mixed liquor in the aeration tank had a good color and the clarifier effluent was clear. The contents of the chlorine contact tank were clear, and the plant was producing a clear effluent. All treatment processes were in very good operation and maintenance condition.

A review of your monthly operating reports covering the period January 2005 through March 2008 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
July 2005	001	CBOD 5 day	30D Conc	10	13.	7/1/2005
August 2005	001	CBOD 5 day	30D Conc	10	15.	8/1/2005
August 2005	001	CBOD 5 day	30D Qty	0.57	.6595	8/1/2005
August 2005	001	CBOD 5 day	7D Conc	15	16.	8/8/2005
September 2005	001	CBOD 5 day	30D Conc	10	23.	9/1/2005
September 2005	001	CBOD 5 day	7D Conc	15	23.	9/8/2005

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.  
Environmental Engineer  
Division of Surface Water

DWS/mt

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Congress Lake Club