



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 27, 2008

RE: SUMMIT COUNTY  
FRANKLIN TOWNSHIP  
DUTT FAMILY PROPERTIES, INC.  
CEI/NOV  
5134 SOUTH MAIN STREET  
OHIO EPA NO. 3PW00028\*BD

Mr. Jason Dutt  
P.O. Box 208  
Doylestown, OH 44230

Dear Mr. Dutt:

On June 19, 2008, this office conducted a Compliance Evaluation Inspection (CEI) at the wastewater treatment plant serving the two apartment buildings owned by Dutt Family Properties, Inc. The wastewater treatment plant consists of a 465 gallon trash trap, a 1500 gpd extended aeration plant, a dosing chamber, a 146 square foot surface sand filter, and a 475 gallon chlorination/dechlorination tank. The plant discharges into an unnamed tributary of Nimisila Reservoir.

During the inspection, the building which encloses the extended aeration tank was locked. Therefore, the aeration tank could not be seen, but it could be heard that it was running. There did appear to be many solids in the chlorination/dechlorination tank which should only contain clear, treated effluent.


A review of the electronic Discharge Monitoring Reports (eDMR's) submitted for the wastewater treatment plant from January 1, 2006, through May 2008 revealed the following numeric effluent violations:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2007	Total Suspended Solids	30D Conc	12	13.	3/1/2007
August 2006	Dissolved Oxygen	1D Conc	6.0	5.8	8/15/2006
June 2006	Dissolved Oxygen	1D Conc	6.0	5.3	6/20/2006
March 2008	Total Suspended Solids	30D Conc	12	15.	3/1/2008
March 2008	Nitrogen, Ammonia (NH3)	30D Conc	3.0	10.6	3/1/2008
March 2008	Nitrogen, Ammonia (NH3)	7D Conc	4.5	10.6	3/22/2008
March 2008	Nitrogen, Ammonia (NH3)	30D Qty	0.03	.04815	3/1/2008
March 2008	Nitrogen, Ammonia (NH3)	7D Qty	0.04	.04815	3/22/2008
August 2007	Dissolved Oxygen	1D Conc	6.0	5.3	8/28/2007
June 2007	Dissolved Oxygen	1D Conc	6.0	5.7	6/13/2007
December 2007	Total Suspended Solids	30D Conc	12	19.	12/1/2007
December 2007	Total Suspended Solids	7D Conc	18	19.	#####

Mr. Jason Dutt  
Dutt Family Properties, Inc.  
June 27, 2008  
Page 2

Please be advised that the above mentioned instances of noncompliance are subject to enforcement pursuant to ORC 6111. In the future, please send letters explaining the reason for an effluent violation, and the planned actions to resolve the situation. See Section III of your NPDES permit concerning noncompliance notification. The violations may also be lessened if your Certified Operator were to sample more often and average the results. If you have any questions, please contact this office at (330) 963-1151.

Sincerely,



Jennifer S. Bennage  
Environmental Engineer  
Division of Surface Water

JSB/mt

cc: Tom LaPlante, Summit County Health Dept.  
Denny White, Certified Operator