



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

December 17, 2007

RE: STARK COUNTY  
PERRY TWP  
PJ LOHR ELEMENTARY SCHOOL  
3PT00100

Mr. Jim Hodinka  
Assistant Superintendent  
PJ Lohr Elementary School  
5300 Richville Drive  
Navarre, OH 44662

Dear Mr. Carver:

On December 13, 2007, this writer conducted a compliance evaluation inspection of your wastewater treatment plant located at 5300 Richville Drive. At the time of the inspection the plant appeared to be in good working condition. The discharge was flowing at approximately 1 to 2 gpm and was clear. No visual problems were noted. Pictures are attached. Below is a summary of compliance for the time period of October 2005 through August 2006 as detected by our SWIMS tracking system:

Numerical Violations

<u>Parameter</u>	<u>Limit</u>	<u>Result</u>	<u>Date</u>
Total Suspended Solids30D Qty	0.45	.64951	2/1/2007
Nitrogen, Ammonia (NH330D Conc	3.0	27.8	2/1/2007
Total Suspended Solids30D Conc	12	66.	2/1/2007
Nitrogen, Ammonia (NH330D Qty	0.11	.27358	2/1/2007
Nitrogen, Ammonia (NH37D Qty	0.17	.27358	2/8/2007
Nitrogen, Ammonia (NH37D Conc	4.5	27.8	2/8/2007
Total Suspended Solids7D Conc	18	66.	2/8/2007
Nitrogen, Ammonia (NH330D Qty	0.11	.28717	3/1/2007
Nitrogen, Ammonia (NH330D Conc	3.0	28.1	3/1/2007
Total Suspended Solids30D Conc	12	32.	3/1/2007
Nitrogen, Ammonia (NH37D Qty	0.17	.28717	3/8/2007
Total Suspended Solids7D Conc	18	32.	3/8/2007
Nitrogen, Ammonia (NH37D Conc	4.5	28.1	3/8/2007

Our files do not contain the noncompliance notifications required in Part III, Section 12 for the above listed violations. Failure to notify is considered a separate violation for each event. If you should have any questions, feel free to contact this writer at (330) 963-1136.

Sincerely,

Philip P. Rhodes, P.E.  
Environmental Engineer  
Division of Surface Water

PPR/mt

attachment

File: Semi-Public\ PJ Lohr Elementary School

PJ Lohr school 12/13/2007

