



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 7, 2007

RE: SUMMIT COUNTY
COPLEY TOWNSHIP
COPLEY TOWNE CENTRE
COMPLIANCE EVALUATION INSPECTION/
NOTICE OF VIOLATION LETTER
NPDES NO. 3PR00381

CERTIFIED MAIL

Ms. Noula Kountis
Copley Towne Centre
2360 Copley Road
Akron, OH 44320

Dear Ms. Kountis:

On November 6, 2007, a Compliance Evaluation Inspection (CEI) was conducted at the above referenced wastewater treatment plant. According to our files, the existing wastewater treatment system consists of a discharging extended aeration tank.

During the inspection the following conditions were noted: The extended aeration plant was running, but the aeration tank color appeared to be light with solids. The grating over the tanks was badly rusted, and for safety reasons should be replaced as soon as possible.

Furthermore, you are in noncompliance with your NPDES permit's compliance schedule. According to your compliance schedule, an appropriately sized trash trap, dosing chamber with elapsed time meters, surface sand filters, aerated sludge holding tank, and chlorination/dechlorination tank were to be constructed by September 1, 2005. Prior to construction of these components, a permit-to-install (PTI) application with detail plans was to be submitted to this office. Enclosed for your convenience is another copy of your NPDES permit.

Review of the self monitoring reports from November 2005 through November 2007 revealed the following numeric effluent violations:


Parameter	Limit Type	Limit	Reported Value	Violation Date
Chlorine, Total Residu	1D Conc	0.019	.35	8/1/2006
Total Suspended Solids	30D Conc	12	31.	3/1/2007
Total Suspended Solids	7D Conc	18	31.	3/1/2007
Nitrogen, Ammonia (NH3)	30D Conc	3.0	5.7	3/1/2007
Nitrogen, Ammonia (NH3)	7D Conc	4.5	5.7	3/1/2007
Chlorine, Total Residu	1D Conc	0.019	.05	6/1/2006
Total Suspended Solids	30D Conc	12	23.	12/1/2006
Total Suspended Solids	7D Conc	18	23.	12/1/2006

Ms. Noula Kountis
Copley Towne Centre
November 7, 2007
Page 2

<u>Parameter</u>	<u>Limit Type</u>	<u>Limit</u>	<u>Reported Value</u>	<u>Violation Date</u>
Total Suspended Solids	30D Conc	12	16.	8/1/2007
Fecal Coliform	30D Conc	1000	6900.	8/1/2007
Fecal Coliform	7D Conc	2000	6900.	8/1/2007
Chlorine, Total Residu	1D Conc	0.019	.15	8/1/2007
Total Suspended Solids	30D Conc	12	16.	6/1/2007

Please be advised that the above mentioned instances of noncompliance are subject to enforcement pursuant to ORC 6111. Please notify this office by December 3, 2007, of your intent to address the aforementioned effluent violations and compliance schedule noncompliance. If you have any questions, please contact this office at (330) 963-1151.

Sincerely,



Jennifer S. Bennage
Environmental Engineer
Division of Surface Water

JSB/mt

enclosure

cc: Bob Hasenyager, Summit County Health Dept.
Sue Schultz, Copley Twp. Zoning Dept.

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

**NOULA KOUNTIS
 COPLEY TOWN CENTRE
 2360 COPLEY ROAD
 AKRON OH 44320**

2. Article Number **7004 2510 0004 5044 9559 (BENNAGE 11/8/07)**
(Transfer from service label)

COMPLETE THIS SECTION ON DELIVERY

A. Signature  Agent
 Addressee

B. Received by (Printed Name) C. Date of Delivery

D. Is delivery address different from item 1? Yes
 If YES, enter delivery address below: No

3. Service Type
 Certified Mail Express Mail
 Registered Return Receipt for Merchandise
 Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee) Yes

PS Form 3811, February 2004

Domestic Return Receipt

102595-02-M-1540

7004 2510 0004 5044 9559

**U.S. Postal Service™
 CERTIFIED MAIL™ RECEIPT**
(Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com®

(Faint tracking number)

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark
Here

Sent To **NOULA KOUNTIS**
COPLEY TOWN CENTRE
 Street, Apt. No.,
 or PO Box No.
 City, State, ZIP+4

PS Form 3800, June 2002

See Reverse for Instructions