



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 19, 2009

RE: STARK COUNTY
LAWRENCE TOWNSHIP
CLAY'S PARK
13190 PATTERSON ROAD
NPDES #3PR00280

Ms. Peggy Clay
Clay's Park
13190 Patterson Road
North Lawrence, OH 44666

Dear Ms. Clay:

On November 17, 2009, this office conducted an inspection of the wastewater treatment system serving your facility. Present during the inspection were this writer and Greg Graves, Clay's Park.

The existing sewage treatment system consists of a 4,000 gallon trash trap followed by a 30,000 gallon flow equalization tank, 70,000 gallon extended aeration plant, dosing chamber, 5,000 square foot surface sand filter, chlorine contact tank with a tablet chlorinator and dechlorinator, a 10,600 gallon sludge holding tank and sludge drying beds. The system discharges to Fox Run.

At the time of the inspection, the treatment system had been shut down for the off season. Liquid is kept in the treatment tanks to prevent collapse and floating of the tanks. The surface sand filters were in good condition. The contents of the chlorine contact tank were clear.

An air line which serves one of the aeration tanks has been repaired since the last inspection.

A review of your discharge monitoring reports (DMRs) covering the period May 2008 through September 2009 revealed the following effluent violation:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2009	001	Dissolved Oxygen	1D Conc	6.0	5.8	6/6/2009

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

pc: Todd Ascani, Stark County Health Department
Ed Hoover, Clay's Park

File: Semi-Public/Clay's Park