

**Environmental  
Protection Agency**

**Governor  
Lt. Governor  
Director**

September 16, 2011

RE: SUMMIT COUNTY  
BOSTON TWP.  
MIDWAY TRAILER PARK  
5115 AKRON-CLEVELAND RD  
3PV00131\*AD

**NOTICE OF VIOLATION**

Sylvia Trecaso, Owner  
Midway Trailer Park  
1439 Broad Blvd.  
Cuyahoga Falls, OH 44223


Dear Ms. Trecaso:

As you know, your National Pollutant Discharge Elimination System (NPDES) for the above referenced facility was effective on December 1, 2009. The Schedule of Compliance in your NPDES permit directed that construction of a wastewater treatment plant upgrade or a sanitary sewer extension be completed by November 1, 2010. To date, this office has not received detail plans of either option. At one time, it was thought that you were contemplating closing down the trailer park.

According to our database, the NPDES required monthly Discharge Monitoring Reports have not been submitted since September 2010. This office needs to know the status of your facility and wastewater treatment plant. If your wastewater treatment plant is in existence, but not discharging, you are still required to submit monthly Discharge Monitoring Reports (indicating no discharge taking place). If the plant has been properly abandoned and there is no longer a wastewater discharge taking place, this office can terminate your NPDES permit. Thereby, you would be relieved of the monthly effluent submittal requirement.

Please respond in writing to this letter, concerning the status of your wastewater treatment plant and discharge, by October 1, 2011. If you have any questions, please contact this office at (330) 963-1151.

Sincerely,



Jennifer S. Bennage  
Environmental Engineer  
Division of Surface Water

JSB:bo

cc: Tom LaPlante, Summit County Health Dept.