



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 13, 2009

RE: SUMMIT COUNTY
PENINSULA
INDIAN SPRINGS TRAILER PARK
4341 RIVERVIEW ROAD
CEI INSPECTION/NOTICE OF VIOLATION
OHIO EPA NO. 3PV00095*BD

Mr. John Szalay
Indian Springs Trailer Park
4341 Riverview Road
Peninsula, OH 44264

CERTIFIED MAIL

Dear Mr. Szalay:

On February 6, 2009, a Compliance Evaluation Inspection (CEI) was conducted at the wastewater treatment plant serving Indian Springs Trailer Park. The wastewater treatment plant consists of a 3000 gallon trash trap, a 9900 gallon aerated flow equalization tank, a 22500 gpd extended aeration treatment plant, a 3000 gallon dosing chamber, a 1898 square surface sand filter, a 1890 gallon chlorination/dechlorination tank, and a 5000 gallon aerated sludge holding tank.

Because of the heavy snow, a thorough inspection could not take place. It was noted that the plant was running, and there were lots of solids on the surface sand filter.

Review of your electronic Discharge Monitoring Reports from February 2007 through February 2009 revealed the following numeric effluent violations:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2007	CBOD 5 day	30D Qty	0.85	1.04088	2/1/2007
May 2007	Dissolved Oxygen	1D Conc	6.0	5.8	5/9/2007
June 2007	Dissolved Oxygen	1D Conc	6.0	5.	6/20/2007
August 2007	Dissolved Oxygen	1D Conc	6.0	5.8	8/8/2007
August 2007	Dissolved Oxygen	1D Conc	6.0	5.1	8/29/2007
June 2008	Dissolved Oxygen	1D Conc	6.0	.03	6/18/2008
September 2008	Dissolved Oxygen	1D Conc	6.0	4.4	9/24/2008
October 2008	Dissolved Oxygen	1D Conc	6.0	5.5	10/1/2008

Please be advised such instances of noncompliance are subject to enforcement pursuant to ORC 6111.


It is directed your plant operator inform this office, in writing, of the plan of action to alleviate future dissolved oxygen violations. If you have any questions, please contact this office at (330) 963-1151.

Sincerely,

Jennifer S. Bennage
Environmental Engineer
Division of Surface Water

JSB/mt

cc: Steve Howe, Technical Operator, AKE Laboratory Inc.
Tom LaPlante, Summit County Health Dept.



7007 2680 0002 2986 5363

U.S. Postal Service
CERTIFIED MAIL RECEIPT
(Certified Mail Only, No Insurance Coverage)

For delivery information visit our website at www.usps.com

Postage	\$	Postmark Here
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	

Sent To

.....
Street, Apt. No.,
or PO Box No.
.....
City, State, ZIP+4