



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 17, 2008

RE: SUMMIT COUNTY
VILLAGE OF PENINSULA
FISHERS CAFÉ AND PUB
1607 MAIN STREET
OHIO EPA NO. 3PR00299

**NOTICE OF VIOLATION/
O&M INSPECTION**

Mr. Richard Fisher, G.M.
Fishers Café and Pub
P.O. Box 176
Peninsula, OH 44264

Dear Mr. Fisher:

On June 11, 2008, an operation and maintenance inspection was conducted at the wastewater treatment plant serving Fishers Café and Pub. During the inspection, the plant was in extremely poor condition and was very odorous. The mixed liquor in the extended aeration tank was too dark in color. The clarifier was completely full of solids. The surface sand filters were clogged with septic effluent and sludge, and there was a hose leading from the filters to the parking lot. The entire grounds around the plant were heavily overgrown with weeds and grass. The plant's grating is still badly rusted, which is a safety hazard and liability.

It is directed you immediately have the entire wastewater treatment system, including the sand filters, pumped by a certified septic hauler. You must contact this office to conduct a follow-up inspection after the pumping is completed.

Please note that your effective NPDES permit's Compliance Schedule states that detail plans with a paid PTI application shall be submitted to Ohio EPA by August 1, 2008. The detail plans shall include, at a minimum, an appropriately sized flow equalization tank, aerated sludge holding tank, additional air supply in the aeration tanks, and new surface sand filter sand. **Please call me by June 23, 2008, to inform me of the Professional Engineer you have hired to design the required plant upgrade.**

Please be advised that failure to comply with the Compliance Schedule in your NPDES permit, and failure to adequately operate and maintain your wastewater treatment plant is cause for an enforcement action pursuant to Chapter 6111 of the Ohio Revised Code. If enforcement proceeds, not only would the plant upgrade still be required, but a civil monetary penalty usually is required. If you have any questions, please contact this office at (330) 963-1151.

Sincerely,

Jennifer S. Bennage
Environmental Engineer
Division of Surface Water

JSB/mt

cc: Village of Peninsula
Tom LaPlante, Summit County Health Department
Ken Lott, Certified WWTP Operator

Get New Data

Limit Type	Violation Date			
June 2006	Total Suspei 30D Conc	12	33.	6/1/2006
June 2006	Total Suspei 7D Conc	18	33.	6/15/2006
June 2006	Total Suspei 30D Qty	0.11	.37472	6/1/2006
June 2006	Total Suspei 7D Qty	0.17	.37472	6/15/2006
June 2006	Nitrogen, An 30D Qty	0.01	.01011	6/1/2006
June 2006	Nitrogen, An 7D Qty	0.01	.01011	6/15/2006
June 2006	CBOD 5 da 30D Conc	10	19.	6/1/2006
June 2006	CBOD 5 da 7D Conc	15	19.	6/15/2006
June 2006	CBOD 5 da 30D Qty	0.09	.21575	6/1/2006
June 2006	CBOD 5 da 7D Qty	0.14	.21575	6/15/2006
June 2006	Chlorine, To 1D Conc	0.019	.61	6/19/2006
March 2007	Total Suspei 30D Conc	12	62.	3/1/2007
March 2007	Total Suspei 7D Conc	18	62.	3/15/2007
March 2007	Total Suspei 30D Qty	0.11	.70401	3/1/2007
March 2007	Total Suspei 7D Qty	0.17	.70401	3/15/2007
March 2007	Nitrogen, An 30D Conc	3.0	11.5	3/1/2007
March 2007	Nitrogen, An 7D Conc	4.5	11.5	3/15/2007
March 2007	Nitrogen, An 30D Qty	0.03	.13058	3/1/2007
March 2007	Nitrogen, An 7D Qty	0.04	.13058	3/15/2007
March 2007	CBOD 5 da 30D Conc	10	34.	3/1/2007
March 2007	CBOD 5 da 7D Conc	15	34.	3/15/2007
March 2007	CBOD 5 da 30D Qty	0.09	.38607	3/1/2007
March 2007	CBOD 5 da 7D Qty	0.14	.38607	3/15/2007
March 2007	Dissolved O: 1D Conc	6.0	3.	3/19/2007
December 2	Total Suspei 30D Conc	12	17.	12/1/2006
December 2	Total Suspei 30D Qty	0.11	.19304	12/1/2006
December 2	Total Suspei 7D Qty	0.17	.19304	12/8/2006
December 2	Nitrogen, An 30D Conc	3.0	3.6	12/1/2006
December 2	Nitrogen, An 30D Qty	0.03	.04088	12/1/2006
December 2	Nitrogen, An 7D Qty	0.04	.04088	12/8/2006
December 2	CBOD 5 da 30D Qty	0.09	.11355	12/1/2006
December 2	Dissolved O: 1D Conc	6.0	3.2	#####
June 2007	Total Suspei 30D Conc	12	15.	6/1/2007
June 2007	Total Suspei 30D Qty	0.11	.17033	6/1/2007
June 2007	Total Suspei 7D Qty	0.17	.17033	6/15/2007
June 2007	Nitrogen, An 30D Conc	1.0	1.18	6/1/2007
June 2007	Nitrogen, An 30D Qty	0.01	.0134	6/1/2007
June 2007	Nitrogen, An 7D Qty	0.01	.0134	6/15/2007
June 2007	Chlorine, To 1D Conc	0.019	.52	6/18/2007



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 6, 2007

RE: SUMMIT COUNTY
VILLAGE OF PENINSULA
FISHERS CAFÉ & PUB
1607 MAIN STREET
OHIO EPA PERMIT #3PR00299

Mr. Richard Fisher
Fishers Café & Pub
P.O. Box 176
Peninsula, OH 44264

Dear Mr. Fisher:

Your National Pollutant Discharge Elimination System (NPDES) permit expired on September 30, 2006. Enclosed are the required NPDES renewal forms, Form 1 and 2E, and the Antidegradation Addendum. Please submit the completed forms to this office by November 20, 2007, along with a \$200 permit renewal fee, paid to the Treasurer of State of Ohio.

If you have any questions, please contact this office at (330) 963-1151.

Sincerely,

Jennifer S. Bennage
Environmental Engineer
Division of Surface Water

JSB/mt

enclosures