



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

April 17, 2008

RE: SUMMIT COUNTY  
CITY OF GREEN  
GREENTREE PLACE  
4866 MASSILLON ROAD  
COMPLIANCE EVALUATION INSPECTION  
OHIO EPA NO. 3PR00103\*DD

Mr. Jean Hobbs  
Greentree Place  
P.O. Box 157  
North Canton, OH 44232

Dear Mr. Hobbs:

On April 16, 2008, a Compliance Evaluation Inspection (CEI) was conducted at the wastewater treatment plant serving Greentree Place. According to our files, the wastewater treatment plant consists of a pump station, 2000 gallon trash trap, 14,000 gpd extended aeration treatment plant, 1300 gallon aerated sludge holding chamber, 556 gallon dosing chamber, 595 square foot surface sand filter, and chlorination/dechlorination tank. The plant discharges into an unnamed tributary of Nimisila Creek, which flows to the Tuscarawas River.

At the time of the inspection, it appeared that one of the surface sand filters was being refurbished. The other half of the filter needed weeded and raked of dry solids. The effluent in the chlorination/dechlorination tank appeared to be clear of visible solids. Overall, the plant appeared to be in satisfactory operating and maintenance condition.

Review of the self monitoring reports from January 2006 through March 2008 revealed the following numeric effluent violations:


Parameter	Limit Type	Limit	Reported Value	Violation Date
Total Suspended Solids	30D Conc	12	22.	3/1/2007
Total Suspended Solids	7D Conc	18	22.	3/8/2007
Total Suspended Solids	30D Conc	12	14.	2/1/2007
CBOD 5 day	30D Conc	10	58.	3/1/2006
CBOD 5 day	7D Conc	15	58.	3/1/2006
CBOD 5 day	30D Qty	0.26	.8577	3/1/2006
CBOD 5 day	7D Qty	0.4	.8577	3/1/2006
Fecal Coliform	30D Conc	1000	15300.	8/1/2007
Fecal Coliform	7D Conc	2000	15300.	8/15/2007

Mr. Jean Hobbs  
Greentree Place  
April 17, 2008  
Page 2

Please be advised that the above mentioned instances of noncompliance are subject to enforcement pursuant to ORC 6111. In the future, please send letters explaining the reason for an effluent violation, and the planned actions to resolve the situation. See Section III of your NPDES permit concerning noncompliance notification.

Also, please be aware that your wastewater treatment plant is required to be abandoned when public sanitary sewers become available. If you have any questions, please contact this office at (330) 963-1151.

Sincerely,



Jennifer S. Bennage  
Environmental Engineer  
Division of Surface Water

JSB/mt

cc: Tom LaPlante, Summit County Health Dept.  
Paul Pickett, City of Green Engineer