



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 21, 2007

RE: BAZETTA CHRISTIAN CHURCH  
TRUMBULL COUNTY  
PERMIT NO. 3PR00249

Reverend Paul Leone  
Church Pastor  
4131 Bazetta Rd.  
Cortland, OH 44410

Dear Reverend Leone:

On May 22, 2007, an inspection of the above referenced facility's wastewater treatment system was conducted. No one was present during the inspection.

During the inspection, the following items were noted:

1. All treatment units appeared to be operational.
2. Both the sludge return line and the skimmer return line were working properly.
3. Mr. Brian Mosko, from Valley Environmental Lab, is currently operating the wastewater treatment system.
4. Mr. Mosko also collects the effluent samples and submits the data electronically through Ohio EPA's Surface Water Information Management System.
5. The surface sand filter beds were free vegetation.
6. Scum build-up was present behind the weir in the settling tank. This scum should be removed.
7. The chlorination dispensing unit was out of chlorination tablets and the tablets in the dechlorination unit were all caked up. These units should be maintained weekly.

This office has recently reviewed your self-monitoring reports covering the period November 1, 2005, through May 31, 2007, for the referenced facility. Our review indicates violations of the terms and conditions of your National Pollutant Discharge Elimination System (NPDES) permit. The specific instances of noncompliance are as follows:

**Limit Violations**

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3	30D Conc	4.0	7.3	3/1/2006
001	00610	Nitrogen, Ammonia (NH3	1D Conc	6.0	7.3	3/3/2006
001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	5.95	6/1/2006
001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.25	5.95	6/6/2006
001	00530	Total Suspended Solids	30D Conc	12	15.	12/1/2006
001	00530	Total Suspended Solids	30D Qty	0.23	.28388	12/1/2006
001	00300	Dissolved Oxygen	1D Conc	6.0	5.5	12/4/2006

Reverend Paul Leone  
Bazetta Christian Church  
June 21, 2007  
Page 2


### Frequency Violations

Violation Date	Station	Reporting Code	Parameter	Sample Frequency	Expected	Reported
11/1/2005	001	00530	Total Suspended Solids	1/Quarter	1	0
11/1/2005	001	00610	Nitrogen, Ammonia (NH3	1/Quarter	1	0
11/1/2005	001	31616	Fecal Coliform	1/Quarter	1	0
11/1/2005	001	80082	CBOD 5 day	1/Quarter	1	0
11/1/2005	001	50060	Chlorine, Total Residu	1/Quarter	1	0
11/1/2005	001	00300	Dissolved Oxygen	1/Quarter	1	0

Please be advised that such instances of noncompliance may be cause for enforcement actions pursuant to the Ohio Revised Code, Chapter 6111.

Should you have any comments or questions concerning this letter, please feel free to call me at (330) 963-1143.

Respectfully,



Michael W. Stevens  
Environmental Engineer  
Division of Surface Water

MWS/mt