



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 20, 2007

RE: MATHEWS SCHOOL DISTRICT
MATHEWS HIGH SCHOOL
PERMIT NO. 3PT00085
NEAL ELEMENTARY SCHOOL
PERMIT NO. 3PT00086
VIENNA & FOWLER TOWNSHIPS

CERTIFIED MAIL

Mr. Joe Polonus
Mathews Board of Education
P.O. Box 157
Vienna, OH 44473

Dear Mr. Polonus:

On May 15, 2007, inspections of the above referenced wastewater treatment systems were conducted. The inspections were conducted to evaluate the performance of the treatment systems in accordance with their respective National Pollutant Discharge Elimination System (NPDES) permits.

The following items were noted:

1. The treatment system at each facility does not meet Ohio EPA's current standards.
2. Each NPDES wastewater permit contained a schedule of compliance to submit detail plans to upgrade the respective treatment system. To date, detail plans to upgrade these treatment systems have not been received by this office.
3. Mathews High School has been in violation of its NPDES permit limits every month since December 2001.
4. Neal Elementary School has been in violation of its NPDES permit limits since June 1, 2003.
5. This office is recommending that our legal department initiate enforcement action for failure to upgrade the treatment systems to meet current standards as required by the expired permits. Typically, Directors Final Findings & Orders are issued requiring the upgrade and may include a penalty.
6. This office has received reports from the Trumbull County Health Department that the septic tank serving Mathews High School has been damaged. Sewage system improvements to address this situation must be completed prior to the 2007-2008 school year.

Should you have any comments or questions concerning this letter, please feel free to call me at (330) 963-1143.

Respectfully,

Michael W. Stevens
Environmental Engineer
Division of Surface Water

MWS/mt

cc: Lee Seiple, Superintendent

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

JOE POLONUS
 MATHEWS BOARD OF EDUCATION
 PO BOX 157
 VIENNA OH 44473

2. Article Number

7004 1160 0001 5934 9183 (STEVENS 6/20/07)

(Transfer from service label)

COMPLETE THIS SECTION ON DELIVERY

A. Signature

X Danelle Sooska Agent Addressee

B. Received by (Printed Name)

Danelle Sooska

C. Date of Delivery

6/21/07

D. Is delivery address different from item 1? Yes

If YES, enter delivery address below: No

3. Service Type

- Certified Mail Express Mail
- Registered Return Receipt for Merchandise
- Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee)

Yes

7004 1160 0001 5934 9183

U.S. Postal Service™
CERTIFIED MAIL™ RECEIPT
 (Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark
Here

Sent To JOE POLONUS
 Street, Apt. No.,
 or PO Box No. MATHEWS BOARD OF EDUCATION
VIENNA OH
 City, State, ZIP+4