



**Environmental
Protection Agency**

1000 N. ... Governor
 300 ... Lt. Governor
 500 ... Director

August 29, 2010

RE: WAYNE COUNTY
 CHIPPEWA TWP
 WESTVIEW MHP
 3PV00031

Ms. Florence Schreibman
 Westview Mobile Home Park
 18592 Edwards Road
 Box 322A
 Doylestown, OH 44230

Dear Ms. Schreibman:

On August 8, 2011, this writer conducted a pre-permit compliance evaluation inspection of the sewage treatment plant serving your facility. Denny White represented your facility during the inspection.

The existing sewage treatment system consists of a trash trap, flow splitter, two aeration tanks, two final clarifiers, chlorine contact tank, effluent pump, one aerated lagoon and one non-aerated lagoon. The system discharges to an unnamed tributary of Silver Creek.

At the time of the inspection, the treatment plant was in good operation. The system was producing what appeared to be a satisfactory effluent.

A review of your Discharge Monitoring Reports (DMRs) covering the period July 2010 through July 2011 revealed the following effluent violations.

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
September 2010	Total Suspended Solids	30D Conc	12	21.3	9/1/2010
September 2010	Fecal Coliform	30D Conc	1000	1600	9/1/2010
September 2010	Total Suspended Solids	1D Conc	18	58	9/28/2010
September 2010	Total Suspended Solids	1D Qty	2.9	4.61013	9/28/2010
November 2010	Total Suspended Solids	30D Conc	12	12.5	11/1/2010
November 2010	CBOD 5 day	30D Conc	10	11	11/1/2010
November 2010	Total Suspended Solids	1D Conc	18	30	11/17/2010
November 2010	Total Suspended Solids	1D Qty	2.9	3.1794	11/17/2010
December 2010	CBOD 5 day	1D Conc	15	24	12/1/2010
December 2010	pH	1D Conc	6.5	6.3	12/8/2010
December 2010	pH	1D Conc	6.5	6.3	12/15/2010
December 2010	pH	1D Conc	6.5	6.4	12/22/2010
January 2011	pH	1D Conc	6.5	6.3	1/5/2011
January 2011	pH	1D Conc	6.5	6.3	1/12/2011
January 2011	pH	1D Conc	6.5	6.3	1/19/2011
January 2011	pH	1D Conc	6.5	6.3	1/26/2011
February 2011	pH	1D Conc	6.5	6.3	2/2/2011
February 2011	pH	1D Conc	6.5	6.3	2/9/2011
February 2011	pH	1D Conc	6.5	6.3	2/16/2011
February 2011	pH	1D Conc	6.5	6.3	2/23/2011

Northeast District Office
 2110 East Aurora Road
 Twinsburg, OH 44087-1924

330 | 963 1200
 330 | 487 0769 (fax)
www.epa.ohio.gov

Ms. Florence Schreibman
 Westview Mobile Home Park
 August 30, 2011
 Page 2

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2011	pH	1D Conc	6.5	6.4	3/2/2011
March 2011	pH	1D Conc	6.5	6.4	3/9/2011
June 2011	Nitrogen, Ammonia (NH3)	30D Conc	1.0	4.075	6/1/2011
June 2011	Nitrogen, Ammonia (NH3)	30D Qty	0.2	.29296	6/1/2011
June 2011	CBOD 5 day	1D Conc	15	29.	6/1/2011
June 2011	CBOD 5 day	30D Conc	10	11.75	6/1/2011
June 2011	Dissolved Oxygen	1D Conc	6.0	4.3	6/8/2011
June 2011	Nitrogen, Ammonia (NH3)	1D Conc	1.5	8.1	6/22/2011
June 2011	Nitrogen, Ammonia (NH3)	1D Qty	0.2	.58251	6/22/2011
June 2011	Dissolved Oxygen	1D Conc	6.0	4.2	6/22/2011
July 2011	Nitrogen, Ammonia (NH3)	30D Conc	1.0	3.1225	7/1/2011
July 2011	Nitrogen, Ammonia (NH3)	30D Qty	0.2	.33965	7/1/2011
July 2011	Nitrogen, Ammonia (NH3)	1D Conc	1.5	5.7	7/6/2011
July 2011	Nitrogen, Ammonia (NH3)	1D Qty	0.2	.62566	7/6/2011
July 2011	Dissolved Oxygen	1D Conc	6.0	4.2	7/6/2011
July 2011	Dissolved Oxygen	1D Conc	6.0	5.1	7/13/2011
July 2011	Total Suspended Solids	1D Conc	18	23.	7/20/2011
July 2011	Dissolved Oxygen	1D Conc	6.0	5.7	7/20/2011

As discussed with Mr. White during the inspection, new water quality standards were adopted by Ohio EPA. These rules require changes to be made to the bacteria monitoring and limits in all new and renewed NPDES permits. The new standards will require the implementation of E. coli limits and monitoring requirements. The E. coli standards will be stated in the renewed NPDES permit. Information regarding the new E. coli water quality standards can be found on the Ohio EPA, Division of Surface Water website: www.epa.ohio.gov/dsw.

The renewal NPDES permit for this facility will be public noticed in the near future. You will have 30 days from the date of public notice to submit written comments to Ohio EPA regarding the draft permit.

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely,



Todd Surrena
 Engineering Geologist
 Division of Surface Water

TMS/mt

cc: Denny White, Operator

File: Semi-Public/Wayne/ChippewaTwp/WestviewMHP